From: Lee.Money <Lee.Money@horsham.gov.uk>
Sent: 08 October 2026 12:05:18 UTC+01:00
To: "Nicola.Pettifer" <Nicola.Pettifer@horsham.gov.uk>
Subject: RE: DISC/26/0309 Land at Campsfield Linfield Close Southwater ENVH response

Hi Nic

Thanks for the consultation on the CEMP.

There's not much detail on the noise and dust monitoring arrangements.

For noise please can they confirm they will comply with the guidance given BS5228:2009. Control of Noise and Vibration on Construction and Open sites and what specific measures they will take.
For dust please can you ask them to confirm that they will comply with the Highly recommended measures as set out in section 8.2 of the IAQM Guidance on the Assessment of Dust from Demolition and Construction 2024.

Regards

Lee

Lee Money

Team Leader Pollution

Telephone: 01403 215410 | 07879 481032
Email: Lee.Money@horsham.gov.uk

Horsham District Council

Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton



From: Lee.Money <Lee.Money@horsham.gov.uk>
Sent: 29 September 2026 15:12

To: Lee.Money <Lee.Money@horsham.gov.uk>
Subject: FW: Planning Application Consultation - DISC/26/0309 Land at Campsfield Linfield Close Southwater West Sussex

Approval of details reserved by conditions 8 (CEMP) and 11 (CEMP: Biodiversity) to approved application DC/25/0102

Lee Money

Team Leader Pollution

Telephone: 01403 215410 | 07879 481032
Email: Lee.Money@horsham.gov.uk

Horsham District Council



From: Planning <planning@horsham.gov.uk>
Sent: 22 September 2026 16:24
To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>
Subject: Planning Application Consultation - DISC/26/0309

Please see the attached consultation letter from Horsham District Council
Re:DISC/26/0309

Telephone:
Email: planning@horsham.gov.uk

Horsham District Council