RE: DISC/25/0123 Upper Beeding Pharmacy High Street Upper Beeding - EH consultation response

30 April 2025 13:45

Hi Steve

I'm happy with the details of the proposed sound insulation mitigation scheme. As the proposal is for a listed building, I accept full compliance with the condition limit of 5dB above the standard required in the building regulations may not be deliverable.

However, condition 5 also requires details of post construction sound insulation verification to be carried out. Please can the applicant supply additional details on how this requirement will be met.

Thanks

Lee

Lee Money
Team Leader Pollution

Telephone: 01403 215410 | 07879 481032
Email: Lee.Money@horsham.gov.uk

Horsham District Council