From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 19 December 2024 14:53
To: Planning
Subject: Discharge of Consultation requirements for Planning application No. DC/22/1059 Ransoms Station Road Pulborough West Sussex

Categories: Consultations

FAO - Nicola Pettifer

Dear Nicola,

I have looked at the plans for planning application No. DC/22/1059 for the erection of a three storey building to provide 8no flats with associated access, parking, bin store and cycle store, checked to location and we have a fire hydrant within the required distance, I have attached a screen shot of our mapping to show the fire hydrant location, which shows it is 35m to the front of the property at Swan Corner and 85m to the rear car park area, so the supply of water for firefighting meets with the requirements. Therefor the consultation for this application has been suitably answered and the consultation can be discharged.



Regards

Ian

Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
Office 0330 222 4499 [redacted]
Web www.westsussex.gov.uk/fire
Email frs.waterandaccess@westsussex.gov.uk
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his
Click here to find out why we use pronouns in our signatures



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.