From: Lee.Money <Lee.Money@horsham.gov.uk>
Sent: 22 May 2025 14:23:38 UTC+01:00
To: "Halima.Chowdhury" <Halima.Chowdhury@horsham.gov.uk>
Subject: RE: DC/25/0672 Ashurst Church of England School School Lane Ashurst EH response

Hi Halima

Thanks for the consultation.

If the application is approved I would recommend the following conditions are applied:

- The air source heat pumps hereby approved shall be operated in night/low power model between 23:00 and 07:00 hours
- Only one air source heat pump shall be operated between 23:00 and 07:00 hours

Regards

Lee

Lee Money

Team Leader Pollution

Telephone: 01403 215410 | 07879 481032
Email: Lee.Money@horsham.gov.uk

Horsham District Council

Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

From: Planning <planning@horsham.gov.uk>
Sent: 22 May 2025 10:38
To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>; Gareth.Jones <Gareth.Jones@horsham.gov.uk>
Subject: Planning Application Consultation - DC/25/0672

Please see the attached consultation letter from Horsham District Council Re:DC/25/0672

Telephone:
Email: planning@horsham.gov.uk



Horsham District Council

Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton