From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 20 February 2024 11:13
To: Planning
Subject: Planning consultation - DC/23/2326 Wood End Farm Ifield Wood Ifield West Sussex RH11 0LE

Categories: Consultations

FAO: Halima Chowdhury

Dear Halima,

Having viewed the details for planning application no. DC/23/2326 for the erection of 1no. cattle barn and cattle handling system with concrete base; evidence is required to show suitable access to the new build Barn can be achieved and a turning facility available to enable a fire appliance to turn and make their exit, conforming with the requirement of Approved Document B (AD-B) Volume 2 B5 section 15. From the information provided, it is unclear if these requirements have been met.

Regards

Ian

Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
Office 0330 222 4499 **Mobile** 07921 291051
Web www.westsussex.gov.uk/fire
Email frs.waterandaccess@westsussex.gov.uk
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his
Click here to find out why we use pronouns in our signatures



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.