Subject: FW: DC/24/0687

From: Lee.Money <Lee.Money@horsham.gov.uk>
Sent: 18 July 2024 10:12
To: Marie.Riggs <Marie.Riggs@horsham.gov.uk>
Subject: RE: DC/24/0687

Hi Marie

The pump speed is inverter controlled so I would assume that the noise for the unit will be lower during periods of reduced demand. This is something applicant should be able to confirm with the manufacturer.

Lee

Lee Money
Team Leader Environmental Protection

Telephone: 01403 215410 | 07879 481032
Email: Lee.Money@horsham.gov.uk

Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton