From: Richard Cruise <Richard.Cruise@westsussex.gov.uk>
Sent: 16 September 2024 11:59:45 UTC+01:00
To: "Amanda.Wilkes" <Amanda.Wilkes@horsham.gov.uk>
Subject: Tunnel Linings

Good morning Amanda,

Following on from our telephone conversation I can confirm the following.

Any linings to any tunnels that are on or form a means of escape from the building must show fire resistance certification. This is obviously so that people can safely escape from the building in the event of a fire.

Kind regards

Rich

Richard Cruise AIFireE MIFSM DipFD
Senior Fire Safety Inspecting Officer
Building Regulations & Complex Buildings Team
West Sussex Fire & Rescue Service

Phone 0330 2226621 **Mobile** 07788 538520
Web www.westsussex.gov.uk/fire
Email richard.cruise@westsussex.gov.uk
Worthing Fire Station, Ardsheal Road, Worthing BN14 7RN

LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.