From: FRS Water and Access [redacted]
Sent: 02 May 2025 12:49
To: Planning
Subject: Planning consultation - DC/24/1965 Abbots Leigh Washington Road Storrington West Sussex RH20 4AF

Categories: Consultations

FAO: Kate Turner

Dear Kate,

Having viewed the plans for the planning application no. DC/24/1695 for the outline application for the erection of 1No. dwelling with associated private garden space, car parking and landscaping with all matters reserved apart from access: the nearest fire hydrant for the supply of water for firefighting is 215-metres away, 40-metres further than the 175-metre distance required for a commercial premises. If an alternative water supply for firefighting is to be considered it will need to conform with the details identified in Approved Document-B (AD-B) Volume 1: B5 section 14 and agreed with West Sussex Fire & Rescue Service.

Regards
Ian

Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
Office 0330 222 4499 [redacted]
Web www.westsussex.gov.uk/fire
[redacted]
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his
Click here to find out why we use pronouns in our signatures



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.