Horsham District Council

Mr Ben Kirk
Manorwood
Suite 114
26 The Hornet
Chichester
PO19 7BB

Our ref:	DISC/25/0118
Your ref:	The Old dairy conditions
Email:	planning@horsham.gov.uk
Direct Line:	01403 215429
If Calling Please ask for:	Bethan Tinning
Date:	30th May 2025

Dear Sir/Madam,

Town and Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure England) Order 2015

Approval of details reserved by conditions 3 and 4 to approved application DC/25/0114

Home Farmhouse Cowfold Road Coolham West Sussex

The Authority has considered your application, and I can confirm that the submitted information is acceptable pursuant to the following condition(s):

3. **Pre-Commencement (Slab Level) Condition**: No development above ground floor slab level shall commence until a management and maintenance plan for the rainwater harvesting system has been submitted to and approved in writing by the Local Planning Authority. The management and maintenance plan shall include the following details:

- Detail on the likely contaminants associated with the rainwater harvesting system,

- Detail on the type of treatment that will be installed on the supply with information clearly indicating that it is appropriate for the amount of water being used and the likely contaminants.

- Detail on the proposed sampling and testing regime, undertaken in accordance with Private Water Supplies (England) Regulations 2016 (or subsequent superseding equivalent), and taking into account the likely contaminants, as detailed above, along with detail on how any failure of any samples will be investigated and managed.

- Detail on the maintenance, servicing and cleaning of the tanks, water treatment equipment, pumps, all pipework etc for the lifetime of the development along with regularity of servicing/maintenance and clarification what steps will be taken in the event of equipment failure. This should include any reactivation of the system after it has been out of use due to lack of rainfall/use.

- Details, including a plan or schematic, showing the supply - storage tanks, treatment etc, and means to record the total water consumption of each unit

- Detail on the continuity of supply during dry periods extending beyond 35 days.

- Arrangements for keeping written records of all sampling, results of analysis, inspection, cleaning, and maintenance.

The management and maintenance plan shall be operated in full at all times. No alterations or revisions to the approved management plan shall be implemented without the written approval of the Local Planning Authority.

Reason: To ensure the development is water neutral to avoid an adverse impact on the Arun Valley SACSPA and Ramsar sites in accordance with Policy 31 of the Horsham District Planning Framework (2015), Paragraph 186 of the National Planning Policy Framework (2023), its duties under the Conservation of Habitats and Species Regulations 2017 (as amended), and s40 of the NERC Act 2006 (Priority Habitats & Species).

Date of approval - 30th May 2025

4. **Pre-Commencement (Slab Level) Condition**: No development above ground floor slab level shall commence until full details of the water efficiency measures and rainwater/greywater harvesting system required by the approved water neutrality strategy (Water Neutrality Statement received 24.01.2025) have been submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the development is water neutral to avoid an adverse impact on the Arun Valley SACSPA and Ramsar sites in accordance with Policy 31 of the Horsham District Planning Framework (2015), Paragraphs 179 and 180 of the National Planning Policy Framework (2021), its duties under the Conservation of Habitats and Species Regulations 2017 (as amended), and s40 of the NERC Act 2006 (Priority Habitats & Species).

Date of approval - 30th May 2025

The development shall be implemented in accordance with the approved plans and details listed in the schedule below.

Schedule of plans/documents:

Plan Type	Description	Drawing Number	Received Date
Supporting Docs	Water Neutrality Report and Water Management Plan		04.04.2025

This letter constitutes a legal document which should be regarded as an addendum to the original planning application.

If you have any queries or require further information, please do not hesitate to contact the Case Officer.

Yours faithfully



Emma Parkes
Head of Development and Building Control