

From: Lee.Money <Lee.Money@horsham.gov.uk>
Sent: 15 April 2026 12:43:34 UTC+01:00
To: "Shazia Penne" <Shazia.Penne@horsham.gov.uk>
Subject: RE: DISC/26/0115 Merryhill Storrington Road Thakeham EnvH response

Hi Shazia

Thanks for the consultation for condition 4 of approved application DC/25/0944.

The manufacturers specifications give a noise level of 31 dBA 10m for the J6LC56CV1 condenser unit. Given the distance to neighbouring noise sensitive receptors it is unlikely that there will be any adverse noise impact from the installation of the external condenser unit.

Regards

Lee

Lee Money

Team Leader Pollution

Telephone: 01403 215410 | 07879 481032

Email: Lee.Money@horsham.gov.uk



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB

Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton



From: Planning <planning@horsham.gov.uk>
Sent: 14 April 2026 14:15
To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>
Subject: Planning Application Consultation - DISC/26/0115

Please see the attached consultation letter from Horsham District Council
Re:DISC/26/0115

Telephone:

Email: planning@horsham.gov.uk



Horsham District Council, Alberty House, Springfield Road, Horsham, West Sussex RH12 2GB

Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton