From: Lee.Money
Sent: 10 June 2024 16:11
To: Marie.Riggs
Cc: Planning
Subject: DC/24/0687 103 St Leonards Road Horsham West Sussex RH13 6AP EH response

Categories: Consultations

Hi Marie

I have reviewed the MCS020 calculation provided for the Air Source Heat Pump

Generally I am satisfied there would be no adverse noise impacts from the daytime operation of the operation of the air source heat pump. However, I have been contacted by a resident concerned about noise impacts for the operation of the air source heat pump. Accordingly for night time operation I would recommend that the air source heat pump air is operated in low power/setback mode between 23:00 and 07:00 hours.

Regards

Lee

Lee Money
Team Leader Environmental Protection
[redacted]