Tony Winn *BEng (Hons), ACABE*
Structural Engineer

3 Deepdene Lodge
Hopewood Park
Deepdene Avenue
Dorking, Surrey
RH5 4FZ
tonywinn11@gmail.com
M: 07788 404371

14th August 2024

To whom it may concern,

RE: Delspride Kent Street – existing foundations

The current proposal will involve not touching the existing footings. As shown within the structural calculations, the loading for the proposed scheme will be less than the existing load, hence the loads on the foundations will be less. The scheme will effectively involve making the roof trusses more robust.

Yours sincerely,

T. Winn

Tony Winn.

cabe