From: simon@si-tecplans.co.uk
Sent: 21 April 2024 20:55
To: Jacques.Burrowes
Subject: RE: DC/24/0171 - Additional Information
Attachments: DWG 2.pdf

Follow Up Flag: Follow up
Flag Status: Flagged

Amended Plans attached

From: Jacques.Burrowes <Jacques.Burrowes@horsham.gov.uk>
Sent: Friday, March 22, 2024 10:20 AM
To: simon@si-tecplans.co.uk
Subject: RE: DC/24/0171 - Additional Information

Hello,

The plans do not seem to tally with the indicated dimensions from the specs you provided on the spreadsheet. The drawings measure the unit 1m in height yet the dimensions of the unit from the spreadsheet indicate the unit to be 550mm in height. Additionally, the unit's width and depth appear to be wrong on the drawing too. The unit is also indicated at 1.2m above the ground which looks to be incorrect from images. I have attached my measurement drawing to show this.

Can accurate plans be resubmitted that tally with the spec of the unit.

Thanks

Jacques Burrowes
Planning Technician

Telephone: 01403 215180
Email: Jacques.Burrowes@horsham.gov.uk

Horsham District Council

Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

From: simon@si-tecplans.co.uk <simon@si-tecplans.co.uk>
Sent: 21 March 2024 17:18
To: Jacques.Burrowes <Jacques.Burrowes@horsham.gov.uk>
Subject: RE: DC/24/0171 - Additional Information

The client would like to leave the unit as it is proposed

From: Jacques.Burrowes <Jacques.Burrowes@horsham.gov.uk>
Sent: Thursday, March 21, 2024 11:10 AM

To: simon@si-tecplans.co.uk
Subject: RE: DC/24/0171 - Additional Information

Good morning,

Is it possible that this unit can be mounted on the ground? This would help attenuate the noise from the unit as at the moment it can fire directly towards the neighbouring garden at its current height and would look less obtrusive. With the unit on the ground, the fencing would help in baffling the sound.

Let me know if this is possible and whether you'll be submitting revised plans with the unit on the ground.

Best

Jacques Burrowes
Planning Technician

Telephone: 01403 215180
Email: Jacques.Burrowes@horsham.gov.uk

Horsham District Council

Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

---

From: simon@si-tecplans.co.uk <simon@si-tecplans.co.uk>
Sent: 20 March 2024 20:30
To: Jacques.Burrowes <Jacques.Burrowes@horsham.gov.uk>
Subject: RE: DC/24/0171 - Additional Information

Items as requested

From: Jacques.Burrowes <Jacques.Burrowes@horsham.gov.uk>
Sent: Tuesday, March 19, 2024 11:39 AM
To: simon@si-tecplans.co.uk
Subject: DC/24/0171 - Additional Information

Good morning,

Is it possible you can send me the specs of the air-con unit at 103 Rushams Road so that our Environmental Health Officer is able to assess the proposal.

Best

Jacques Burrowes
Planning Technician

Telephone: 01403 215180
Email: Jacques.Burrowes@horsham.gov.uk

Horsham District Council

Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

From: Jacques.Burrowes
Sent: 16 February 2024 13:40
To: simon@si-tecplans.co.uk
Subject: DC/24/0171 - Additional Information

Good morning,

Is it possible you can send me the specs of the air-con unit at 103 Rushams Road so that our Environmental Health Officer is able to assess the proposal.

Best

Jacques Burrowes
Planning Technician

Telephone: 01403 215180
Email: Jacques.Burrowes@horsham.gov.uk

Horsham District Council


Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

Disclaimer


IMPORTANT NOTICE This e-mail might contain privileged and/or confidential information. If you have received this e-mail in error, please notify the sender and delete the e-mail immediately; you may not use or pass it to anyone else. Whilst every care has been taken to check this outgoing e-mail for viruses, it is your responsibility to carry out checks upon receipt. Horsham District Council does not accept liability for any damage caused. E-mail transmission cannot guarantee to be secure or error free. This e-mail does not create any legal relations, contractual or otherwise. Any views or opinions expressed are personal to the author and do not necessarily represent those of Horsham District Council. This Council does not accept liability for any unauthorised/unlawful statement made by an employee. Information in this e mail may be subject to public disclosure in accordance with the law. Horsham District Council cannot guarantee that it will not provide this e mail to a third party. The Council reserves the right to monitor e-mails in accordance with the law. If this e-mail message or any attachments are incomplete or unreadable, please telephone 01403 215100 or e-mail contact@horsham.gov.uk. Any reference to "e-mail" in this disclaimer includes any attachments.

This email has been scanned for viruses and malware, and may have been automatically archived by **Mimecast Ltd**.







Right Side



Roof Plan




Fron



Rear

Elevations



Scale Bar 1:100

Amendments	Date

Client **Mr & Mrs Bell**

Site Address

103 Rushams road
Horsham
West Sussex
RH12 2NY

Proposal

Drawing Title **Elevations**

Date Drawn **S. Burrows**

Scales **1:100**

DWG NO.	REV