total utility connections

3, 4 & 5 Castlebridge
5-19 Cowbridge Road East
Cardiff
CF11 9AB

enquiries@tucltd.co.uk
(029) 2132 0350
www.tucltd.co.uk

Horsham District Council
Horsham District Council (Planning)
Parkside, Chart Way
Horsham
RH12 1RL

11th February 2024

Dear Sir/Madam

Electricity Act 1989 – The Overhead Lines (Exemption) (England & Wales) Regulations 2009

This notice is being given to your Council under The Overhead Lines (Exemption) (England & Wales) Regulation 2009.

Under this exemption, your Authority is required to determine, within 6 weeks of receipt of this notice, whether it is considered that the proposal is likely to have a significant adverse effect on the environment.

The works associated with this proposal will commence on site on or after the expiry of the required six weeks notice, unless it becomes necessary to apply to the Secretary of State for Trade and Industry for his consent.

Particulars of proposal:

- Installation of relocated HV Pole, PMT and associated Overhead Lines.
- Installation of HV & LV underground cables from relocated HV pole to new housing development.

Location: Blakers Yard, Worthing Road, Horsham, RH13 8NH

Plan No:

- 8200068233 / QID 3200054952,
- 2404018-E-100-SP-Rev C - A

Details of proposal: UKPN to install new HV poles and relocate PMT Dial Post 521227 to the approx. location to the East of the site boundary, as shown on the attached drawings. UKPN to carry out 1x LV and 1x HV pole terminations and LV & HV earthing. Total Utility Connections Ltd. to lay new underground HV and LV cables to new HV Pole.

Yours faithfully

G. Davies

Gemma Davies

Design Engineer

ACCREDITED NERS NATIONAL ELECTRICITY REGISTRATION SCHEME
ACCREDITED GIRS GAS INDUSTRY REGISTRATION SCHEME
ACCREDITED WIRS WATER INDUSTRY REGISTRATION SCHEME
Constructionline Gold Member
Achilles UVDB SILVER PLUS


total utility
connections