From: Graham Wagland <graham@folkesarchitects.co.uk>
Sent: 23 September 2025 09:42:41 UTC+01:00
To: "Halima.Chowdhury" <Halima.Chowdhury@horsham.gov.uk>
Cc: "Euan Clark" <euan@folkesarchitects.co.uk>
Subject: RE: DISC/25/0229, Chantry Mill, Chantry Lane, Storrington,

Morning Halima.

Regarding the above, we wish to keep to the 15mm double glazing to the windows to help with the U-value.
The eaves venting will be the under-tile system and ridge vents will be incorporated rather than tile vents.
The rainwater goods will be cast aluminium instead of plastic.

We will amend the drawings accordingly and re-issue.

Many thanks.

Kind regards.

Graham Wagland
Senior Architectural Technician

folkes architects

LABC Building Excellence AWARDS 2022 Regional Winner

The Old Forge, 6 Church Street, Storrington, West Sussex, RH20 4LA

Tel: 01903 868629 Mob: 07788 376943

www.folkesarchitects.co.uk

Folkes Architects is the trading name for Folkes Architecture & Design Ltd. Company No. 4452101 England. VAT No:835 171827. This e-mail and any files transmitted with it, are intended solely for the use of the persons to whom it is addressed. If you are not one of the intended recipients you must not use, disclose copy or distribute this e-mail. If you have received this email in error, please contact the sender immediately by telephone on the number given above and then delete the message from the system. Any views or opinions expressed here do not necessarily represent those of Folkes Architects unless explicitly stated otherwise. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks on an attachment to this message. We cannot accept liability for any loss or damage caused by software viruses.

From: Euan Clark <euan@folkesarchitects.co.uk>
Sent: 19 September 2025 12:54
To: Graham Wagland <graham@folkesarchitects.co.uk>
Subject: Fw: DISC/25/0229, Chantry Mill, Chantry Lane, Storrington,

From: Halima.Chowdhury <Halima.Chowdhury@horsham.gov.uk>
Sent: Friday, September 19, 2025 12:52 PM
To: Euan Clark <euan@folkesarchitects.co.uk>
Subject: DISC/25/0229, Chantry Mill, Chantry Lane, Storrington,

Dear Euan,

DISC/25/0229,
Chantry Mill, Chantry Lane, Storrington,
Application for Approval of Details Reserved by Condition 2 to approved application DC/24/1467 (Listed Building).

I refer to the above planning application.

Please see below the Council's Conservation Officer's consultation comments and please kindly address the concerns raised.

I would appreciate if the requested information could be provided by 26th September 2025.

Kind regards

Halima Chowdhury

Planning Officer

Telephone: 01403 215059

Email: Halima.Chowdhury@horsham.gov.uk

Horsham District Council will only accept service of documents by email if they are sent to legal@horsham.gov.uk. Any documents sent to individual email addresses will not be accepted under any circumstances.
Communications received after 5pm will be regarded as being served on the next working day.
Please contact us in advance if your email, including any attachments, is going to exceed 30MB.

From: Nicola.Mason <Nicola.Mason@horsham.gov.uk>
Sent: 19 September 2025 10:29

To: Halima.Chowdhury <Halima.Chowdhury@horsham.gov.uk>
Subject: DISC/25/0229 - Chantry Mill

Dear Halima

I am satisfied with the information submitted but would have the following comments:

- The preference would be for slimline double glazing which are usually 14mm thick or less, the proposed windows are 15mm. I would not raise an objection but would ask if the thinner windows has been considered.
- In terms of the insulation to the roof I note the drawings show the eaves to be ventilated by either a continuous 25mm gap or through a proprietary under tile ventilator and either ventilated ridge tiles or venting tiles to match roof tiles in colour as much as possible. Once this has been decided please could the detail be confirmed. The gutters and rain water goods should not be plastic but either cast iron or cast aluminium or cast effect plastic.

Kind regards

Nicola

Nicola Mason

Conservation Officer

Specialists Team - Strategic Planning

Telephone: 01403 215289

Email: Nicola.Mason@horsham.gov.uk

Horsham District Council

Disclaimer

IMPORTANT NOTICE This e-mail might contain privileged and/or confidential information. If you have received this e-mail in error, please notify the sender and delete the e-mail immediately; you may not use or pass it to anyone else. Whilst every care has been taken to check this outgoing e-mail for viruses, it is your responsibility to carry out checks upon receipt. Horsham District Council does not accept liability for any damage caused. E-mail transmission cannot guarantee to be secure or error free. This e-mail does not create any legal relations, contractual or otherwise. Any views or opinions expressed are personal to the author and do not necessarily represent those of Horsham District Council. This Council does not accept liability for any unauthorised/unlawful statement made by an employee. Information in this e mail may be subject to public disclosure in accordance with

the law. Horsham District Council cannot guarantee that it will not provide this e mail to a third party. The Council reserves the right to monitor e-mails in accordance with the law. If this e-mail message or any attachments are incomplete or unreadable, please telephone 01403 215100 or e-mail customer.services@horsham.gov.uk. Any reference to "e-mail" in this disclaimer includes any attachments.

This email has been scanned for viruses and malware, and may have been automatically archived by **Mimecast Ltd**.