From: Andrew.Bush [redacted]
Sent: Thursday, December 12, 2024 12:51 PM
To: [redacted]
Cc: [redacted]
Subject: [EXTERNAL] RE: North Horsham Strategic Development Location

CAUTION: This email originated from outside of the organisation. Do not click links or open attachments unless you recognise the sender and know the content is safe.

Hi Sarah,

Thank you for this information, as long as the fencing is in the right location, and permanent I am satisfied that it meets the requirements of the BS. As such, I can advise that I do not have any significant concerns with the manner in which the TPF will be founded to the ground, and the use of wooden posts is in this instance is satisfactory.

Kind regards,

Andy

Andrew Bush
Arboricultural Officer
Specialists Team - Strategic Planning

Telephone: [redacted]
Email: [redacted]

From: [redacted]
Sent: Saturday, December 7, 2024 11:57 AM
To: [redacted]
Cc: [redacted]
Subject: North Horsham Strategic Development Location

Hi Andy,

I am writing to make you aware that the fencing within the North Horsham Strategic Development site is currently - and will be from this point forward, erected on wooden posts sunk into the ground which will support Heras fence panels. This is a minor deviation from scaffolding poles specified in the approved Tree Protection information.

The purpose of the amendment is due to the risk of injury to operatives with the installation of fencing near to over / underground services.



I have confirmed that the fencing is robust and fit for purpose. Panels are attached to the posts and cannot be moved. The larger posts are more rigid therefore they are resistant to vehicle impact without bracing. The fencing therefore meets the requirements of BS:5837.

Provided you are in agreement, future reports will specify wooden pots as the standard.

If you have any questions or queries please do get in touch with me.

Many thanks,

[redacted]

Arboricultural Consultant

[redacted]

Duckworths Arboriculture Ltd.

Disclaimer

IMPORTANT NOTICE This e-mail might contain privileged and/or confidential information. If you have received this e-mail in error, please notify the sender and delete the e-mail immediately; you may not use or pass it to anyone else. Whilst every care has been taken to check this outgoing e-mail for viruses, it is your responsibility to carry out checks upon receipt. Horsham District Council does not accept liability for any damage caused. E-mail transmission cannot guarantee to be secure or error free. This e-mail does not create any legal relations, contractual or otherwise. Any views or opinions expressed are personal to the author and do not necessarily represent those of Horsham District Council. This Council does not accept liability for any unauthorised/unlawful statement made by an employee. Information in this e mail may be subject to public disclosure in accordance with the law. Horsham District Council cannot guarantee that it will not provide this e mail to a third party. The Council reserves the right to monitor e-mails in accordance with the law. If this e-mail message or any attachments are incomplete or unreadable, please telephone 01403 215100 or e-mail contact@horsham.gov.uk. Any reference to "e-mail" in this disclaimer includes any attachments.

This email has been scanned for viruses and malware, and may have been automatically archived by **Mimecast Ltd**.