From: Lee.Money [redacted]
Sent: 29 April 2025 16:58
To: Marie.Riggs [redacted]
Subject: RE: DISC/25/0104 Sleepy Warren Maydwell Avenue EH response

Hi Marie

Hope you are well

Thanks for the consultation request.

To discharge the condition please can the applicant supply further details of the overheating prevention system to be provided by “reverse cooling of Air Source Heat Pumps utilising underfloor pipework.”

I would like confirmation that this approach will meet the requirements of Approved Document O in managing overheating risk at night and occupiers well not have to rely on open windows for thermal comfort.

Thanks

Lee

Lee Money
Team Leader Pollution

[redacted]

Horsham District Council

Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton