

From: Planning@horsham.gov.uk <Planning@horsham.gov.uk>
Sent: 19 June 2026 09:49:44 UTC+01:00
To: "Planning" <planning@horsham.gov.uk>
Subject: Comments for Planning Application EIA/26/0005
Categories: Comments Received

Comments summary

Dear Sir/Madam,

Planning Application comments have been made. A summary of the comments is provided below.

Comments were submitted at 19/06/2026 9:49 AM.

Application Summary

Address:	Land South of Adversane Adversane Lane Adversane West Sussex
Proposal:	EIA Scoping Opinion for a mixed-use development for a new settlement to accommodate 3,200 dwellings, employment uses, community uses and supporting infrastructure.
Case Officer:	Jason Hawkes

[Click for further information](#)

Customer Details

Address: UK Power Networks, Barton Road BURY ST. EDMUNDS

Comments Details

Commenter Type:	Consultee
Stance:	Customer made comments neither objecting to or supporting the Planning Application
Reasons for comment:	
Comments:	We note there are overhead cables on the site running within close proximity to the proposed development. Prior to commencement of work accurate records should be obtained from our Plan Provision Department at UK Power Networks, Fore Hamlet, Ipswich, IP3 8AA.

In the instance of overhead cables within the vicinity, All works should be undertaken in line with GS6 guidelines as published by the HSE

Should any diversion works be necessary because of the development then enquiries should be made to our Customer Connections department. The address is UK Power Networks, Metropolitan house, Darkes Lane, Potters Bar, Herts, EN6 1AG.

You can also find support and application forms on our website
Moving electricity supplies or equipment | UK Power Networks

Kind regards

Telephone:

Email: planning@horsham.gov.uk



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton