[redacted]

[redacted]

Sent: 26 November 2024 15:28

[redacted]

Subject: RE: DC/24/1574 Land at 521105 113285 New Hall Lane Small Dole EH response

Hi Jacques

Thanks for the consultation request for this retrospective application. If the application is approved I would recommend that the following condition is attached:

1. Prior to first occupation of development full details of the rainwater harvesting scheme shall be submitted to and approved in writing by the local planning authority. The scheme shall include:

- Detail on the likely contaminants associated with the rainwater harvesting system,
- Detail on the type of treatment that will be installed on the supply with information clearly indicating that it is appropriate for the amount of water being used and the likely contaminants.
- Details of the risk assessment and proposed sampling and testing regime, undertaken in accordance with Private Water Supplies (England) Regulations 2016 (or subsequent superseding equivalent), and taking into account the likely contaminants, as detailed above, along with detail on how any failure of any samples will be investigated and managed.
- Detail on the maintenance, servicing and cleaning of the tanks, water treatment equipment, pumps, all pipework etc for the lifetime of the development along with regularity of servicing/maintenance and clarification what steps will be taken in the event of equipment failure. This should include any re-activation of the system after it has been out of use due to lack of rainfall/use.
- Details, including a plan or schematic, showing the supply – including a site plan and/or schematic showing location of source, chambers, tanks, distribution network including valves, pipes, consumer premises and means to record the total water consumption of each unit
- Detail on the continuity of supply during dry periods extending beyond 35 days.
- Arrangements for keeping written records of all sampling, results of analysis, inspection, cleaning, and maintenance

Regards

Lee

Lee Money
Team Leader Environmental Protection
[redacted]
Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

Lee Money
Team Leader Environmental Protection

Telephone: 01403 215410 | 07879 481032
Email: Lee.Money@horsham.gov.uk

Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

-----Original Message-----
From: Planning <planning@horsham.gov.uk>
Sent: 26 November 2024 12:48
To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>; Gareth.Jones <Gareth.Jones@horsham.gov.uk>
Subject: Planning Application Consultation - DC/24/1574

Please see the attached consultation letter from Horsham District Council Re:DC/24/1574