
From: Julie Crowhurst [REDACTED]
Sent: 08 April 2026 16:38
To: Planning
Subject: DC/26/0430 - Response to Planning

Importance: High

Categories: Consultations

**DC/26/0430 Horsham Golf Park Denne Park Horsham West Sussex
Removal of condition 33 of previously approved application DC/23/1178. Relating to Water
Neutrality**

SPC Comment: Whilst SPC continues to object to DC/23/1178, the request to remove condition 33 relating to water neutrality must still be subject to conditions on water usage.

Following discussion with the planning officers, we understand their position, and whilst we do not agree with the initial application, we will support their decision to recommend permission, subject to meeting Building Regulation G2 to limit the water usage of each dwelling to no more than 110 litres per person per day. Including a method of monitoring the usage.

Regards

Julie



JULIE CROWHURST

ASSISTANT EXECUTIVE OFFICER

01403 733202
[REDACTED]

Beeson House, 26 Lintot Square, Fairbank Road, Southwater, RH13 9LA

Disclaimer: This email may contain privileged and/or confidential information. If you have received this email in error, please notify the sender and delete the email immediately. You may not use or pass it to a third party. Whilst every care has been taken to check this outgoing email for viruses, it is your responsibility to carry out checks upon receipt. Southwater Parish Council does not accept liability for any damage caused. Read the [full email disclaimer](#).