

[illegible]

7. GRADING CERTIFICATES REQUIRED FOR IMPORTED OR SITE WON CRUSHED MATERIAL TO BE USED AS FILL.

8. PLANT LOAD TESTS (PLUS OTHERS) MUST BE PROVIDED BEFORE DRAINING AND AFTER FILLING AS OUTLINED IN SPECIFICATION.

9. ALL VEGETATION, TOPSOIL, AND DELETERIOUS MATERIAL MUST BE REMOVED.

7. GRADING CERTIFICATES REQUIRED FOR IMPORTED OR SITE WON CRUSHED MATERIAL TO BE USED AS FILL.
8. PLANT LOAD TESTS (PLUS OTHERS) MUST BE PROVIDED BEFORE DRAINING AND AFTER FILLING AS OUTLINED IN SPECIFICATION.
9. ALL VEGETATION, TOPSOIL, AND DELETERIOUS MATERIAL MUST BE REMOVED.

CONCRETE SERVICE YARD	PAV 2.4093 TOP MESH 50mm OVER REINFORCED JOINTED CONCRETE TYPE 1 AGGREGATE
175mm SURFACE	
150mm SUB BASE	
ASPHALT ACCESS ROAD	HRA 55.0 TOP SURF-40/60 GRADE AC 20 DENSE BIN 40/60 GRADE AC 32 BASE 40/60 GRADE TYPE 1 AGGREGATE
40mm SURFACE	
60mm BINDER	
100mm BASE	
150mm SUB-BASE	

- | | |
|-----------------------|---|
| CONCRETE SERVICE YARD | PAV 2.4093 TOP MESH 50mm OVER REINFORCED JOINTED CONCRETE TYPE 1 AGGREGATE |
| 175mm SURFACE | |
| 150mm SUB BASE | |
| ASPHALT ACCESS ROAD | HRA 55.0 TOP SURF-40/60 GRADE AC 20 DENSE BIN 40/60 GRADE AC 32 BASE 40/60 GRADE TYPE 1 AGGREGATE |
| 40mm SURFACE | |
| 60mm BINDER | |
| 100mm BASE | |
| 150mm SUB-BASE | |


- | BLOCK PARKING BAYS | |
|--------------------|----------|
| 80mm | SURFACE |
| 30mm | BEDDING |
| 150mm | SUB-BASE |
-
- | BLOCK | |
|-------|-----------------------|
| | MORTAR BED AND JOINTS |
| | TYPE 1 AGGREGATE |

- | BLOCK FOOTPATHS | |
|-----------------|------------------|
| 50mm | SURFACE |
| 30mm | BEDDING |
| 150mm | SUB-BASE |
| | BLOCK |
| | SAND |
| | TYPE 1 AGGREGATE |

- | TARMAC FOOTPATH | |
|-----------------|----------|
| 25mm | SURFACE |
| 50mm | BINDER |
| 150mm | SUB-BASE |
-
- | | |
|------------------|-------------|
| AC 6 CLOSE SURF | 100/150 GRA |
| AC 20 DENSE BIN | 100/150 GRA |
| TYPE 1 AGGREGATE | |

- 100mm SURFACE
150mm SUB-BASE
10mm TO DUST SELF BINDING
TYPE 1 AGGREGATE

LANDSCAPING



 SITE BOUNDARY

 LINEAR DRAINAGE CHANNEL

SI	SAWM JOINT
DCJ	DEBANGED CONTRACTION JOINT
LJ	LONGITUDINAL JOINT
DEJ	LONGITUDINAL JOINT AT CHAMBER
DJ	ARMOURIED JOINT AT DOORWAY
U	ISOLATION JOINT

