

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 21 September 2026 15:28
To: Planning
Subject: Planning consultation - DC/26/0010 Land North of Girder Bridge Gay Street Lane North Heath RH20 2HW

Follow Up Flag: Follow up
Flag Status: Flagged

Categories: Consultations

FAO: Shazia Penne

Dear Shazia,

Having viewed the plans for the planning application no DC/26/0010 for the Use of land for the stationing of 6 static caravans for residential purposes (to be occupied by Gypsies and Travellers) and associated landscape works; the nearest fire hydrant for the supply of water for firefighting is 470 metres away, 295-metres further than the 175-metre distance required for a domestic premises. If an alternative supply of water for firefighting is to be considered it will need to conform with the details identified in Approved Document-B (AD-B) Volume 1: B5 section 14 and agreed with West Sussex Fire & Rescue Service.

Evidence is also required to show access road and turning facility is meets the required with and capable of supporting 18-Tonne axial weight of AD-B Volume12: B5 section 1.3.

Regards
Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West S

LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to

ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
