From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 01 October 2024 09:57
To: Planning
Subject: Planning consultation - DC/24/1112 Thistledown Cottage Harbolets Road West Chiltington West Sussex RH20 2LG

Categories: Consultations

FAO: Jacques Burrowes

Dear Jacques,

Having viewed the plans for the planning application no DC/24/1112 for the Demolition of existing buildings and erection of 2 x new build dwellings (in the alternative to permission granted under DC/23/1906 Prior Approval of Proposed Change of Use of Agricultural Building to form 2 dwellinghouses); the nearest fire hydrant for the supply of water for firefighting is 265 metres away, 90-metres further than the 175-metre distance required for a domestic premises. If an alternative water supply for firefighting is to be considered it will need to conform with the details identified in Approved Document–B (AD-B) Volume 1: B5 section 14 and agreed with West Sussex Fire & Rescue Service.

Regards

Ian

Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
Office 0330 222 4499 [redacted]
Web www.westsussex.gov.uk/fire
Email frs.waterandaccess@westsussex.gov.uk
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his
Click here to find out why we use pronouns in our signatures



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.