

Bethan.Tinning

From: [REDACTED]
Sent: 04 March 2026 09:58
To: Bethan.Tinning
Subject: RE: DISC/26/0042 Land at 516512 133748 Dorking Road Warnham EH response

Hi Bethan


Thanks or the consultation request.

Sufficient f information has been provided to discharge parts a) and b) of condition 1 to approved application DC/25/0126.

To discharge part c) further information is required on the following:

- Remedial method statement for the removal of the identified and suspected asbestos containing materials on site
- A site plan showing the locations and extent of the geotextile membrane, capping layer and protected supply pipework and their relationship to the boundaries individual plots.

Regards



Horsham District Council, Alberty House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

From: [REDACTED]
Sent: 20 February 2026 14:50
To: [REDACTED]
Subject: FW: Planning Application Consultation - DISC/26/0042 Land at 516512 133748 Dorking Road Warnham

Application for Approval of Details Reserved by Condition 1 (a), (b) and (c) of approved application DC/25/0126.

