From: Sean.Rix <Sean.Rix@horsham.gov.uk>
Sent: 12 October 2026 13:05:59 UTC+01:00
To: "Halima.Chowdhury" <Halima.Chowdhury@horsham.gov.uk>
Subject: DC/26/1450 7 Borough Gate High Street Steyning

Dear Halima,

I am satisfied the replacement of the timber windows with UPVC is acceptable in principle with the condition that the windows are flush fitting with their frames. Some of the drawings indicate that this will be the case and others indicate a storm casement. Please ask for confirmation all windows will be flush fitting with their frame before determining the application.

Regards,
Seán

Seán Rix

Senior Conservation Officer
Specialists Team - Strategic Planning

Telephone: 01403 215276
Email: Sean.Rix@horsham.gov.uk



