Horsham Denne Neighbourhood Council
CONSULTATION COMMENTS

TO:	Horsham District Council – Planning Dept
SITE ADDRESS:	37 East Street, Horsham
PROPOSAL:	Retention of existing restaurant and take away use with extraction flue on rear elevation. (Retrospective).
REFERENCE:	DC/25/0676
RECOMMENDATION:	Objection
SUMMARY OF COMMENTS & RECOMMENDATION: Objection (see main comments)	
MAIN COMMENTS: Horsham Denne Neighbourhood Council has concerns regarding the impact of noise and odours on the nearby residential properties. We note the comments of the Environmental Health officer and also that the noise assessment was carried out without the air condenser working (as per Noise Assessment p.13 fig.5.2.2). Therefore, until the Environmental Health Officer is satisfied that all the mitigation measures are in place, HDNC **objects** to this application.	
ANY RECOMMENDED CONDITIONS: See main comments	
NAME:	
DATE:	19.5.25