[redacted]

From: Sean.Rix
Sent: 06 November 2026 12:21
To: Bethan.Tinning; Planning
Subject: DC/26/1526 Land at 11/12 East Street, Rusper

Categories: Consultations

Dear Bethan,

I am satisfied the proposal for solar panels will not harm the character of the conservation area as long as these are fitted to sit within the roof slope and not on top of the roof tiles. I continue to request that the windows fitted have flush fitting casements and not stormproof casements. Please ask that these two points are confirmed in writing before determining the application.

Regards,
Seán

Seán Rix
Senior Conservation Officer
Specialists Team - Strategic Planning

Telephone: [redacted]
Email: [redacted]

Horsham District Council

Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton