
From: Sean.Rix
Sent: 09 June 2026 13:08
To: Stephen.Astles; Planning
Subject: DC/26/0733 Bottings Farm London Road Henfield

Categories: Consultations

Dear Steve,

As this is a very similar proposal to that agreed under DC/19/2239 I am happy for you to determine positively. I am also satisfied the portion of boundary wall to be removed is not historic and creating an access to the garden will not harm the listed building. I have suggested conditions below.

Regards,
Seán

LB01 Samples of External Materials and Finishes

Pre-Commencement Condition: Prior to relevant work beginning, the following details shall have been submitted to and approved in writing by the Local Planning Authority. The relevant works must not be executed other than in complete accordance with these approved details:

Specifications of external materials and surface finishes.

Reason: As this matter is fundamental to ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB02 Roof Detailing/Junctions

Regulatory Condition: The new roof junctions at ridge, hips, eaves and verges shall be built to reflect traditional detailing including exposed rafter feet, cut verges, bonnet hip tiles and hogs back or half round ridge tiles.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB03 Windows

Regulatory Condition: The new windows fitted in the building hereby permitted shall have timber casements flush fitted with their frames.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB04 Roof Lights

Regulatory Condition: The roof lights hereby permitted shall be metal framed and sit flush with the roof slope. The opening leaf shall be top hung.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB05 Rainwater Goods

Regulatory Condition: All new and replacement rainwater goods shall be cast iron or cast aluminium or cast effect plastic.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

Seán Rix

Senior Conservation Officer

Specialists Team - Strategic Planning

[REDACTED]

[REDACTED]



Horsham District Council, Alberty House, Springfield Road, Horsham, West Sussex RH12 2GB

Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton