From: Lee.Money <Lee.Money@horsham.gov.uk>
Sent: 15 November 2024 11:48:48 UTC+00:00
To: "Kate.Turner" <Kate.Turner@horsham.gov.uk>
Subject: FW: Planning Application Consultation - DC/24/1548 EH response

Hi Kate

Thanks for the consultation request.

The applicant has stated the rainwater harvesting system is only to be used for watering of livestock and for no other purpose. Accordingly, there is no objection to the removal of the condition.

However, the applicant should be advised that if the rainwater system is utilized at a future date to provide either drinking water or water for sanitary purposes then an appropriate treatment system will be required, and the use of the supply will need to be notified to the local authority.

Regards

Lee

Lee Money
Team Leader Environmental Protection
Telephone: 01403 215410 |
07879 481032
Email:Lee.Money@horsham.gov.uk
Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton
-----Original Message-----
From: Planning <planning@horsham.gov.uk>
Sent: 14 November 2024 10:34
To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>; Gareth.Jones <Gareth.Jones@horsham.gov.uk>
Subject: Planning Application Consultation - DC/24/1548

Please see the attached consultation letter from Horsham District Council Re:DC/24/1548