

**From:** Jeimmy Nascimento <jeimmy.nascimento@mclarchitects.co.uk>  
**Sent:** 15 June 2026 10:25:09 UTC+01:00  
**To:** "Halima.Chowdhury" <Halima.Chowdhury@horsham.gov.uk>; "Giles Emmerson" <Giles.Emmerson@morrisandspottiswood.co.uk>  
**Subject:** RE: URGENT - DC/26/0412, 2 Carfax, Horsham, - M&E application extension date noise assessment required  
**Importance:** High

Dear Halima  
Hope this email finds you well

Please see below report requested from our contractor  
Trust this satisfy your request

Kind Regards

RE: Barclays Horsham - External plant noise assessment - URGENT



Chris Plumb <Christopher.Plumb@79group.co.uk>  
To: Giles Emmerson  
Cc: adrian klasinski; Matt Ingram; Warren Wykes; Joana Cuadrado; Michael Clarkson

M&S IT: WARNING! This email originated from outside the organisation and we were unable to verify the sender.

Hi Giles,

Please see below our in office assessment of the existing and proposed.

| Unit                   | Sound Pressure Level<br>dBA |
|------------------------|-----------------------------|
| <b>Existing</b>        |                             |
| REYQ10T7Y1B            | 58                          |
| RZQSG100L8V1B          | 57                          |
| RXS50L2V1B             | 48                          |
| RXS20L2V1B             | 47                          |
| Mitsubishi MXZ-3F68VF4 | 53                          |
| Mitsubishi MXZ-3F68VF4 | 53                          |
| <b>New</b>             |                             |
| REYA12A9               | 61.9                        |
| RZAG35B                | 48                          |
| RZAG35B                | 48                          |
| ERA100AV               | 50                          |

Summary

| Scenario       | Combined SPL (dBA) |
|----------------|--------------------|
| Existing Plant | 62.2               |
| Proposed Plant | 62.1               |
| Change         | -0.1 dBA           |

The proposed installation is therefore approximately 0.1 dBA quieter than the existing installation. This difference is effectively imperceptible and would generally be regarded as acoustically equivalent in a noise assessment.

Explanatory note:

For a proper comparison, the individual sound pressure levels must be combined logarithmically:  
$$L_{total} = 10\log_{10}\left(\sum 10^{L_i/10}\right)$$

Existing Units

58, 57, 48, 47, 53, 53 dBA

Combined level:

$$10\log_{10}(10^{5.8} + 10^{5.7} + 10^{4.8} + 10^{4.7} + 10^{5.3} + 10^{5.3})$$

= 62.2 dBA

New Units

61.9, 48, 48, 50 dBA

Combined level:

$$10\log_{10}(10^{6.19} + 10^{4.8} + 10^{4.8} + 10^{5.0})$$

= 62.1 dBA

Difference

$$62.1 - 62.2 = -0.1 \text{ dBA}$$

Regards

Chris Plumb  
Project Manager

01452 714391 | 07737 640 923  
| [79group.co.uk](http://79group.co.uk)

**Jeimmy Nascimento**  
**Senior Designer**

Tel: 0141 425 1133 | Mobile: 07443668734  
Unit 3, Gateway Court, Dalmarnock, Glasgow, G40 4DS

[www.mclarchitects.co.uk](http://www.mclarchitects.co.uk)

MCLENNAN

CHARTERED ARCHITECTS

a **morris & spottiswood group** company



**Help the environment - do you need to print this email?**

---

**From:** Halima.Chowdhury <Halima.Chowdhury@horsham.gov.uk>

**Sent:** 01 June 2026 18:03

**To:** Giles Emmerson <Giles.Emmerson@morrisandspottiswood.co.uk>; Jeimmy Nascimento <jeimmy.nascimento@mclarchitects.co.uk>

**Subject:** RE: URGENT - DC/26/0412, 2 Carfax, Horsham, - M&E application extension date noise assessment required

**Importance:** High

URGENT

Dear Giles,

**DC/26/0412,  
2 Carfax, Horsham,  
New external platform to host new external condenser units and associated works to new  
ventilation and Air conditioner system within the building.**

I refer to your email below and duly note your comments.

However, a full acoustic consultant's report by a competent professional is required which confirms that the new units would be quieter and more efficient than the existing.

I hope the above information answers your question.

Kind regards

**Halima Chowdhury**

Planning Officer

**Telephone:** 01403 215059

**Email:** [Halima.Chowdhury@horsham.gov.uk](mailto:Halima.Chowdhury@horsham.gov.uk)



---

**Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB**

Telephone: 01403 215100 (calls may be recorded) [www.horsham.gov.uk](http://www.horsham.gov.uk) Chief Executive: Jane Eaton

Horsham District Council will only accept service of documents by email if they are sent to [legal@horsham.gov.uk](mailto:legal@horsham.gov.uk). Any documents sent to individual email addresses will not be accepted under any circumstances.

Communications received after 5pm will be regarded as being served on the next working day.  
Please contact us in advance if your email, including any attachments, is going to exceed 30MB.

---

**From:** Giles Emmerson <[Giles.Emmerson@morrisandspottiswood.co.uk](mailto:Giles.Emmerson@morrisandspottiswood.co.uk)>

**Sent:** 01 June 2026 13:07

**To:** Jeimmy Nascimento <[jeimmy.nascimento@mclarchitects.co.uk](mailto:jeimmy.nascimento@mclarchitects.co.uk)>; Halima.Chowdhury <[Halima.Chowdhury@horsham.gov.uk](mailto:Halima.Chowdhury@horsham.gov.uk)>

**Subject:** RE: URGENT - DC/26/0412, 2 Carfax, Horsham, - M&E application extension date noise assessment required

Hi Halima,

We have already stripped out the existing plant at Horsham and what we are putting back is quieter and more efficient than the existing.

We can request formal confirmation from our MEP contractor for this to assist with your processes

Kind regards

**Giles Emmerson**  
Assistant Project Manager

Tel: 0141 425 1133 | Mobile: 07443 669661

# morris & spottiswood

Creating environments for people to thrive



[morrisandspottiswood.co.uk](http://morrisandspottiswood.co.uk)



Want to see regular updates from Morris & Spottiswood? Follow us on LinkedIn

Glasgow (Registered Office): Unit 3, Gateway Court, Dalmarnock, Glasgow, G40 4DS | Tel: 0141 425 1133

Our locations: Almondvale | Bristol | Glasgow | Huntingdon | Leeds | London | Warrington | Whitstable

Morris & Spottiswood is a limited liability company registered in the United Kingdom under Company Number SC046129

a morris & spottiswood **group** company

**Confidential 24-hour Health & Safety Answer Service: Call 0141 425 4999**



Help the environment - do you need to print this email

**From:** Jeimmy Nascimento <[jeimmy.nascimento@mclarchitects.co.uk](mailto:jeimmy.nascimento@mclarchitects.co.uk)>

**Sent:** 01 June 2026 10:56

**To:** Halima.Chowdhury <[Halima.Chowdhury@horsham.gov.uk](mailto:Halima.Chowdhury@horsham.gov.uk)>

**Cc:** Giles Emmerson <[Giles.Emmerson@morrisandspottiswood.co.uk](mailto:Giles.Emmerson@morrisandspottiswood.co.uk)>

**Subject:** RE: URGENT - DC/26/0412, 2 Carfax, Horsham, - M&E application extension date noise assessment required

Hi Halima

Please take this email as confirmation on the extension date

With regards the noise assessment,

Can you please confirm what information exactly are you looking to have on this document and if you will be satisfied if M^E engineers can confirm just via email that the existing plant dB is no worse than the existing? Or do you need a full acoustic consultant's report?

Kind Regards

**Jeimmy Nascimento**  
**Senior Designer**

Tel: 0141 425 1133 | Mobile: 07443668734  
Unit 3, Gateway Court, Dalmarnock, Glasgow, G40 4DS

[www.mclarchitects.co.uk](http://www.mclarchitects.co.uk)

MCLENNAN

CHARTERED ARCHITECTS

a **morris & spottiswood group** company



**Help the environment - do you need to print this email?**

---

**From:** Jeimmy Nascimento <[jeimmy.nascimento@mclarchitects.co.uk](mailto:jeimmy.nascimento@mclarchitects.co.uk)>

**Sent:** 26 May 2026 10:34

**To:** Halima.Chowdhury <[Halima.Chowdhury@horsham.gov.uk](mailto:Halima.Chowdhury@horsham.gov.uk)>; Giles Emmerson  
<[Giles.Emmerson@morrisandspottiswood.co.uk](mailto:Giles.Emmerson@morrisandspottiswood.co.uk)>

**Subject:** RE: URGENT - DC/26/0412, 2 Carfax, Horsham, - M&E application extension date noise assessment required

**Importance:** High

Hi Halima,  
Please see attached specs downloaded from Daiking web page

[@Giles Emmerson](#)

Can you please assist on sending the noise assessment and confirm on the extension date?

Kind Regards

**Jeimmy Nascimento**  
**Senior Designer**

Tel: 0141 425 1133 | Mobile: 07443668734  
Unit 3, Gateway Court, Dalmarnock, Glasgow, G40 4DS

[www.mclarchitects.co.uk](http://www.mclarchitects.co.uk)

# MCLENNAN

CHARTERED ARCHITECTS

a **morris & spottiswood group** company



**Help the environment - do you need to print this email?**

---

**From:** Halima.Chowdhury <[Halima.Chowdhury@horsham.gov.uk](mailto:Halima.Chowdhury@horsham.gov.uk)>

**Sent:** 26 May 2026 10:02

**To:** Jeimmy Nascimento <[jeimmy.nascimento@mclarchitects.co.uk](mailto:jeimmy.nascimento@mclarchitects.co.uk)>; Giles Emmerson  
<[Giles.Emmerson@morrisandspottiswood.co.uk](mailto:Giles.Emmerson@morrisandspottiswood.co.uk)>

**Subject:** RE: URGENT - DC/26/0412, 2 Carfax, Horsham, - M&E application extension date noise assessment required

**Importance:** High

URGENT

Dear Jeimmy,

**DC/26/0412,  
2 Carfax, Horsham,  
New external platform to host new external condenser units and associated works to new  
ventilation and Air conditioner system within the building.**

I refer to your email below.

Unfortunately, the plans you refer to do not provide the information the Local Planning Authority requires. Drawing named RPT5769\_2026\_HORSHAM CARFAX\_MBR\_3FSD\_1FL\_MECH\_HVAC\_002\_P03 - FIRST FLOOR AC LAYOUT, provides symbols to different components of the units accompanied with the installation instructions relating to the temperature set points. Also, drawing named RPT5769\_2026\_HORSHAM CARFAX\_MBR\_3FSD\_XX\_MECH\_EQUIPSCHED\_001\_P01, lists the schedule of unit's model reference numbers etc. As explained in my previous emails, the Local Planning Authority requires manufacturer's literature on details and specifications of the proposed 4 no. condensers units accompanied with appropriate noise assessment.

I hope the above information provides further clarity on the information required by the Local Planning Authority and would be grateful if these could be provided by 29<sup>th</sup> May 2026.

Kind regards

**Halima Chowdhury**

Planning Officer

**Telephone:** 01403 215059

**Email:** [Halima.Chowdhury@horsham.gov.uk](mailto:Halima.Chowdhury@horsham.gov.uk)



---

**Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB**

Telephone: 01403 215100 (calls may be recorded) [www.horsham.gov.uk](http://www.horsham.gov.uk) Chief Executive: Jane Eaton

Horsham District Council will only accept service of documents by email if they are sent to [legal@horsham.gov.uk](mailto:legal@horsham.gov.uk). Any documents sent to individual email addresses will not be accepted under any circumstances.

Communications received after 5pm will be regarded as being served on the next working day.  
Please contact us in advance if your email, including any attachments, is going to exceed 30MB.

---

**From:** Jeimmy Nascimento <[jeimmy.nascimento@mclarchitects.co.uk](mailto:jeimmy.nascimento@mclarchitects.co.uk)>

**Sent:** 25 May 2026 09:12

**To:** Halima.Chowdhury <[Halima.Chowdhury@horsham.gov.uk](mailto:Halima.Chowdhury@horsham.gov.uk)>; Giles Emmerson <[Giles.Emmerson@morrisandspottiswood.co.uk](mailto:Giles.Emmerson@morrisandspottiswood.co.uk)>

**Subject:** RE: URGENT - DC/26/0412, 2 Carfax, Horsham, - M&E application extension date noise assessment required

**Importance:** High

Dear Halima

Thank you for your email

Units are shown on drawing named RPT5769\_2026\_HORSHAM CARFAX\_

MBR\_3FSD\_1FL\_MECH\_HVAC\_002\_P03 - FIRST FLOOR AC LAYOUT and the spec's are on the drawing named RPT5769\_2026\_HORSHAM CARFAX\_

MBR\_3FSD\_XX\_MECH\_EQUIPSCHED\_001\_P01 both attached on previous email and original submission through portal

[@Giles Emmerson](#)

Can you please provide the noise assessment and confirm that you are happy with extension date?

Kind Regards

**Jeimmy Nascimento**  
**Senior Designer**

Tel: 0141 425 1133 | Mobile: 07443668734  
Unit 3, Gateway Court, Dalmarnock, Glasgow, G40 4DS

[www.mclarchitects.co.uk](http://www.mclarchitects.co.uk)

MCLENNAN

CHARTERED ARCHITECTS

a morris & spottiswood group company



**Help the environment - do you need to print this email?**

---

**From:** Halima.Chowdhury <[Halima.Chowdhury@horsham.gov.uk](mailto:Halima.Chowdhury@horsham.gov.uk)>  
**Sent:** 22 May 2026 18:04  
**To:** Jeimmy Nascimento <[jeimmy.nascimento@mclarchitects.co.uk](mailto:jeimmy.nascimento@mclarchitects.co.uk)>  
**Subject:** URGENT - DC/26/0412, 2 Carfax, Horsham,  
**Importance:** High

URGENT

Dear Jeimmy,

**DC/26/0412,**  
**2 Carfax, Horsham,**  
**New external platform to host new external condenser units and associated works to new ventilation and Air conditioner system within the building.**

Thank you for your email below confirming the status with the condenser units.

Apologies, I do not know what is M&E information? However, having reviewed the content of the attached folder there are no details on the 4 no. condensers units provided with the original submission. The local planning authority requires manufacture details and specifications of the proposed 4 no. condensers units accompanied with appropriate noise assessment.

Given the fact that the determination date is 25<sup>th</sup> May 2026, please can I ask for your written agreement to extend the determination date until 22<sup>nd</sup> June 2026 to allow for consultation on the outstanding information.

I would appreciate an urgent response by today 22<sup>nd</sup> May 2026.

Kind regards

**Halima Chowdhury**

Planning Officer

**Telephone:** 01403 215059

**Email:** [Halima.Chowdhury@horsham.gov.uk](mailto:Halima.Chowdhury@horsham.gov.uk)



---

**Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB**

Telephone: 01403 215100 (calls may be recorded) [www.horsham.gov.uk](http://www.horsham.gov.uk) Chief Executive: Jane Eaton

Horsham District Council will only accept service of documents by email if they are sent to [legal@horsham.gov.uk](mailto:legal@horsham.gov.uk). Any documents sent to individual email addresses will not be accepted under any circumstances.

Communications received after 5pm will be regarded as being served on the next working day.

Please contact us in advance if your email, including any attachments, is going to exceed 30MB.

---

**From:** Jeimmy Nascimento <[jeimmy.nascimento@mclarchitects.co.uk](mailto:jeimmy.nascimento@mclarchitects.co.uk)>

**Sent:** 22 May 2026 13:33

**To:** Halima.Chowdhury <[Halima.Chowdhury@horsham.gov.uk](mailto:Halima.Chowdhury@horsham.gov.uk)>

**Subject:** RE: URGENT - DC/26/0412, 2 Carfax, Horsham,

**Importance:** High

Dear Halima

Many thanks for your message

Yes, the intention is to apply for platform and external units

We have provided all the M&E information with the original submission through the online portal, please see attached file downloaded from Portal

Can you please specify what other information is required?

Kind Regards

**Jeimmy Nascimento**  
**Senior Designer**

Tel: 0141 425 1133 | Mobile: 07443668734  
Unit 3, Gateway Court, Dalmarnock, Glasgow, G40 4DS

[www.mclarchitects.co.uk](http://www.mclarchitects.co.uk)

MCLENNAN

CHARTERED ARCHITECTS

a **morris & spottiswood group** company



**Help the environment - do you need to print this email?**

---

**From:** Halima.Chowdhury <[Halima.Chowdhury@horsham.gov.uk](mailto:Halima.Chowdhury@horsham.gov.uk)>  
**Sent:** 22 May 2026 13:27  
**To:** Jeimmy Nascimento <[jeimmy.nascimento@mclarchitects.co.uk](mailto:jeimmy.nascimento@mclarchitects.co.uk)>  
**Subject:** URGENT - DC/26/0412, 2 Carfax, Horsham,  
**Importance:** High

URGENT

Dear Jeimmy,

**DC/26/0412,**  
**2 Carfax, Horsham,**  
**New external platform to host new external condenser units and associated works to new ventilation and Air conditioner system within the building.**

I refer to the above application.

Unfortunately, there is ambiguity in the application details. Please kindly confirm if this planning application is seeking permission for the external plants as well as the new external platform, as there are no details provided for 4 no. condensers proposed to be placed on this structure. If the new condenser units are part of this application then details and specification of these units needs to be provided.

I would be grateful for an urgent response by today 22<sup>nd</sup> May 2026.

Kind regards

**Halima Chowdhury**

Planning Officer

**Telephone:** [01403 215059](tel:01403215059)

**Email:** [Halima.Chowdhury@horsham.gov.uk](mailto:Halima.Chowdhury@horsham.gov.uk)



---

**Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB**

Telephone: 01403 215100 (calls may be recorded) [www.horsham.gov.uk](http://www.horsham.gov.uk) Chief Executive: Jane Eaton

Horsham District Council will only accept service of documents by email if they are sent to [legal@horsham.gov.uk](mailto:legal@horsham.gov.uk). Any documents sent to individual email addresses will not be accepted under any circumstances.

Communications received after 5pm will be regarded as being served on the next working day.

Please contact us in advance if your email, including any attachments, is going to exceed 30MB.

## Disclaimer

IMPORTANT NOTICE This e-mail might contain privileged and/or confidential information. If you have received this e-mail in error, please notify the sender and delete the e-mail immediately; you may not use or pass it to anyone else. Whilst every care has been taken to check this outgoing e-mail for viruses, it is your responsibility to carry out checks upon receipt. Horsham District Council does not accept liability for any damage caused. E-mail transmission cannot guarantee to be secure or error free. This e-mail does not create any legal relations, contractual or otherwise. Any views or opinions expressed are personal to the author and do not necessarily represent those of Horsham District Council. This Council does not accept liability for any unauthorised/unlawful statement made by an employee. Information in this e mail may be subject to public disclosure in accordance with the law. Horsham District Council cannot guarantee that it will not provide this e mail to a third party. The Council reserves the right to monitor e-mails in accordance with the law. If this e-mail message or any attachments are incomplete or unreadable, please telephone 01403 215100 or e-mail [customer.services@horsham.gov.uk](mailto:customer.services@horsham.gov.uk). Any reference to "e-mail" in this disclaimer includes any attachments.

This email has been scanned for viruses and malware, and may have been automatically archived by **Mimecast Ltd.**