[redacted]

From: Amy.Furness
Sent: 30 October 2026 17:04
To: Planning
Cc: Daniel.Holmes
Subject: RE: Planning Application Consultation - DISC/26/0224

Categories: Consultations

Good afternoon,

On review of the amended Drainage Strategy, HDC Drainage have No Objection.

The implementation of the Drainage Strategy is subject to Building Regulations/ Building Control and must be installed correctly. Foul drainage must be installed in a protected from crushing, as the drainage strategy indicates that the foul lines will be installed below the access track.

Kind regards,

Amy Furness
Drainage Officer

Telephone: [redacted]
Email: [redacted]

Horsham District Council

Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

From: Planning <planning@horsham.gov.uk>
Sent: 12 October 2026 11:58
To: Drainage <Drainage@horsham.gov.uk>; Amy.Furness [redacted]
Subject: Planning Application Consultation - DISC/26/0224

Please see the attached consultation letter from Horsham District Council Re:DISC/26/0224

Telephone:
Email: planning@horsham.gov.uk

Horsham District Council

Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton