

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 23 July 2026 12:18
To: Planning
Subject: Planning consultation - DC/26/1129 Kingsland, School Lane, Shipley, Horsham, RH13 8PL

Categories: Consultations

FAO: Halima Chowdhury

Dear Halima,

Having viewed the details for planning application No. DC/26/1129 for temporary campsite from 1st to 31st August 2026; the nearest fire hydrant to the site is 160m away from the site. There is no access route for a fire appliance to reach the site and as such and would attend from the main road or parking area to attend any fire incidents that may occur in these areas. A fire appliance will not drive across grassland or any surface not capable of supporting 18-Tonne axial weight of the fire appliance. The camping site is just within 90m distance from the fire appliance location; the camping plots should be suitably separated to ensure any fire that occurs does not spread to other tents.

This information should be included in the fire risk assessment for the site, and suitable control measures put in place.

Regards
Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** [REDACTED]

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West S

LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
