## East Lodge – Main house and annexe images of flow restriction images – 29.5.24

| | | |
|---|---|---|
| 1 | Main house E/S shower fitted with 6 Lpm flow restrictor. |  |
| 2 | Main House E/S WC - cistern water level reduced and tank bank bag fitted to give 4.5L fill volume |  |

| | | |
|---|---|---|
| 3.1 | Main house bath fitted with lowered overflow to give max fill volume of 90L - (1) |  |
| 3.2 | Main house bath fitted with lowered overflow to give max fill volume of 90L - (2) |  |

| | | |
|---|---|---|
| 4 | Main house family shower fitted with 6 Lpm flow restrictor |  |
| 5 | Main House family WC - cistern water level reduced and tank bank fitted to give 4.5L fill volume. |  |

| | | |
|---|---|---|
| 6 | Annexe shower fitted with 6 Lpm flow restrictors to main head and hand shower. |  |
| 7 | Annexe basin fitted with 3.8 Lpm flow restrictor |  |

| | | |
|---|---|---|
| 8 | Annexe kitchen tap fitted with 6 Lpm flow restrictor |  |
| 9 | Annexe WC: Affine back to wall WC 6/4L concealed cistern. Refer to attached technical literature and images to the right. |   |