




Impermeable Areas Draining -Scale 1:500



Site Investigation Locations -Scale 1:500

Infiltration Test Results

Test Ref	On site Depth (m)	Test 1 (m/sec)	Test 2 (m/sec)	Test 3 (m/sec)	Lowest Value (m/h)	Infiltration Zone
TP1	1.95	1.47 E-05	2.04 E-05	1.92 E-05	0.05292	1
TP2	1.20	1.35 E-06	1.18 E-06	1.23 E-06	0.004248	2
TP3	1.70	2.52 E-06	n/a	n/a	0.009072	3
TP4	2.35	2.84 E-05	3.27 E-05	3.76 E-05	0.10224	4
TP5	1.60	1.32 E-05	8.33 E-06	n/a	0.029988	5
TP6	2.45	3.31 E-05	2.20 E-05	2.02 E-05	0.07272	6
TP7	1.90	3.14 E-05	2.22 E-05	n/a	0.07992	7
SO102A	1.90	1.02 E-05	7.96 E-06	n/a	0.028656	6
SA104	2.70	9.26 E-06	6.90 E-06	n/a	0.024840	7
TP5	1.20	7.18 E-06	7.42 E-06	7.77 E-06	0.025848	

Groundwater Monitoring Results

Monitoring Well - 5.0m	Well Depth m bgl	29-11-2024 m bgl	11-12-2024 m bgl	08-01-2025 m bgl	03-02-2025 m bgl	03-03-2025 m bgl
WS1	2.30	Dry	Dry	Dry	Dry	Dry
WS2	1.80	Dry	Dry	Dry	Dry	Dry
WS3	2.70	Dry	Dry	Dry	Dry	Dry
WS4	2.70	Dry	Dry	Dry	Dry	Dry
WS5	3.00	Dry	Dry	Dry	Dry	Dry

SAFETY, HEALTH & ENVIRONMENTAL INFORMATION
CDM Regulations 2015

In addition to the hazards/risks normally associated with the type of work detailed on this drawing note should be made of the following:

- Working in vicinity of live highway
- Services to be located prior to any excavation work being undertaken
- Working on live foul sewers
- Deep excavations

It is assumed that all works will be carried out by a competent contractor working, where appropriate, to an approved method statement. Contractor is not relieved of any of his obligations under all applicable health and safety regulations.

Rev.	A	21.04.26	First Issue	KN
Date			Details	Initials

Drawing Status
FOR INFORMATION

Project
CLAYTON KENNELS
STORRINGTON



KAZYS NARBUTAS CONSULTING
Civil Engineering Consultant
Unit 24b, Romsey Industrial Estate, Greatbridge Road, Romsey, Hants. SO51 0HE
Telephone: 07973 231468 Email: kazys.n@knc.email

Drawing Title Engineering Details Drained Areas & Site Investigation Locations				
Drawn	Checked	Scales	Paper Size	Date
KN		1:500	A2	04.26
Job No.	Drawing No.	Revision		
KNC2602	500-01	A		