

CERTIFICATE OF INSPECTION

INVOICE	SITE
Wimblehurst Hotel Wimblehurst Road Horsham RH12 2ED	Wimblehurst Hotel Wimblehurst Road Horsham RH12 2ED
CONTACT:	CONTACT:
TEL: Minday	TEL: Minday
Inspection Type: Six Monthly	

System Category:	M	L1	L2	L3	L4	L5	P1	P2
T= Tested F = Failed		SERVICE DETAILS - Fire Alarm						
26.74	Charge Voltage							
T	Conventional - Addressable					Make: Kentec		
1	No. of Zones - Loops							
T	Detectors					Make: Apollo xp95/apollo s65		
T	Call Points					Make: Apollo addressable and conventional		
N/A	230v Smoke Detectors							
N/A	Linked to Arc							
N/A	Signal Received							
T	Mains Disconnected / Indicators - Buzzers Ok							
T	O/C All alarm circuits							
T	O/C All zone circuits							
T	Controls tested e.g. Codes - Key Switch Ok							
N/A	Visual Alarms Tested							
T	Audible Alarms Tested							
T	Batteries disconnected / Indicators - Buzzers Ok							
T	Zone chart displayed							
Ancillaries								
T	FRA Documents Online			Fire Log Book Complete?			Y	
0	Visits per year			If No - Reason				
Quiescent Current	0.3 A			Alarm Current			3.02 A	
Standby Period	24 Hrs			Battery Required			12v7ah x2 AH	
Year of Battery	2022			Battery Fitted			12v7ah x2 AH	
(QUIESCENT X STANDBY) + (ALARM CURRENT) X 1.25								
10.975								
System Satisfactory				Y				