From: Lee.Money <Lee.Money@horsham.gov.uk>
Sent: 13 March 2025 16:39:31 UTC+01:00
To: "Robert.Hermitage" <Robert.Hermitage@horsham.gov.uk>
Subject: RE Planning Application Consultation - DISC/25/0015 Thistledown Cottage Harbolets Road West Chiltington EH response

Hi Rob

Thanks for the consultation request.

The Preliminary Contamination Risk Assessment provided by EAS Ltd and dated February 2025 is satisfactory and Part a) to condition 1 can be discharged.

However I would not recommend that the condition is fully discharged until the applicant confirms in writing that :

- No soft landscaping is to be carried out within the site
- All Asbestos Containing Materials (ACMs) have been removed from the site in accordance with appropriate safety and disposal precautions and no asbestos containing materials have been retained on site.

Regards

Lee

Lee Money

Team Leader Pollution

Telephone: 01403 215410 | 07879 481032
Email: Lee.Money@horsham.gov.uk

PLEASE NOTE: We have moved, please see the new Council address below.
Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

From: Planning <planning@horsham.gov.uk>
Sent: 13 March 2025 13:32
To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>; Gareth.Jones <Gareth.Jones@horsham.gov.uk>
Subject: Planning Application Consultation - DISC/25/0015

Please see the attached consultation letter from Horsham District Council
Re:DISC/25/0015

Telephone:
Email: planning@horsham.gov.uk





PLEASE NOTE: We have moved, please see the new Council address below.
Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton