HORSHAM DISTRICT COUNCIL CONSULTATION

TO:	Horsham District Council – Planning Dept
LOCATION:	Aquarius, The Street, Bramber
DESCRIPTION:	
REFERENCE:	DC/23/1886
RECOMMENDATION:	~~Advice~~ / No Objection ~~/ Objection / More Information / Modification / Refusal~~
SUMMARY OF COMMENTS & RECOMMENDATION: Proposal will fail to preserve the character of the conservation area.	
MAIN COMMENTS: Dear Shazia, I am content the redesigned replacement dwelling will reinforce the character of this part of the conservation area and the proposal can now be supported in heritage terms. I have suggested conditions below. Regards, Seán	

ANY RECOMMENDED CONDITIONS:

LB01 Samples of External Materials and Finishes

Pre-Commencement Condition: Prior to relevant work beginning, the following details shall have been submitted to and approved in writing by the Local Planning Authority. The relevant works must not be executed other than in complete accordance with these approved details:

Specifications of external materials and surface finishes.

Reason: As this matter is fundamental to ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB02 Roof Detailing/Junctions

Regulatory Condition: The new roof junctions at ridge, hips, valleys, eaves and verges shall be built to reflect traditional detailing including exposed rafter feet, cut verges, bonnet hip and valley tiles and hogs back or half round ridge tiles.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB03 Windows

Regulatory Condition: The new windows fitted in the building hereby permitted shall have casements flush fitted with their frames if manufactured in timber or plastic.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB04 Roof Lights

Regulatory Condition: The roof lights hereby permitted shall be metal framed and sit flush with the roof slope.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB05 Rainwater Goods

Regulatory Condition: All new and replacement rainwater goods shall be cast iron or cast aluminium or cast effect plastic.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special

architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).	
NAME:	Seán Rix
DEPARTMENT:	Conservation
DATE:	06.11.23