

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 15 September 2026 13:53
To: Planning
Subject: DISC/26/0239 - Discharge of Condition 8 Fire Hydrants: Rascalls Farm Shipley Road Southwater Horsham West Sussex RH13 9BG

Categories: Consultations

FAO: Kate Turner

Dear Kate,

Providing the fire hydrants (FHs) indicated on the plan submitted for planning consultation No. DISC/26/0239 are in place and ready for use prior to any occupation of any dwellings, the condition will be met and can be discharged. Unfortunately, on too many occasions West Sussex Fire & Rescue Service (WSFRS) are not informed fire hydrants are in place and ready for use prior to dwellings being occupied, which then increases the risk to life and property in the event of a fire occurring. So, please ensure WSFRS are informed when FHs are ready for use

Regards
Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** [REDACTED]

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West S

LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
