Registered Office:
Newington House
237 Southwark Bridge Road
London SE1 6NP

Registered in England and Wales No: 3870728

Company:
UK Power Networks
(Operations) Limited

Our Ref: 8500298253

Planning Office
Horsham District Council
Parkside
Chart Way
Horsham
West Sussex
RH12 1RL

Also sent by email to
planning@horsham.gov.uk

23rd September 2024

Dear Sir/Madam

Electricity Act 1989
Overhead Line (Exemption) (England & Wales) Regulations 2009
Statutory Instrument 2009 No. 640 Electricity, Paragraph 3 (1)

This notice is being given to your Council under The Overhead Lines (Exemption) (England & Wales) Regulation 2009.

Under this exemption, your Authority is required to determine, within 6 weeks of receipt of this notice, whether it is considered that the proposal is likely to have a significant adverse effect on the environment.

The works associated with this proposal will commence on site on or after the expiry of the required six weeks notice, unless it becomes necessary to apply to the Secretary of State for Trade and Industry for his consent.

Particulars of proposal:

Location: The Field Brighton Road BN5 9ST

Plan No: 8500298253

Details of proposal:

- To upgrade the existing low voltage overhead line between poles 634472/634473 to 635348 to 95ABC
- To install two new stay wires on pole 635348

[redacted]

Stessie Aristide
Connections Surveyor
South Eastern Power Networks plc
[redacted]

Return Address:
South Eastern Power Networks plc
Property & Consents
c/o Energy House
Hazelwick Avenue
Three Bridges
Crawley
RH10 1EX