CERTIFICATION OF PRE-COMPLETION SOUND INSULATION TESTING

DATE TASK ACCESSED
18 April 2023

Task number	76347	**Password**	QSOOPG	**Registered organisation number**	147
Task registration date	18/04/2023			**Registered organisation name**	Sonic Element
Client	Mr Wahi Dizzaman			**Registered organisation address**	Little Hoplands, Island Road, Hersden, Canterbury, CT3 4HD
Site address	First Floor Flat, 8 East Street, Horsham, RH12 1HL			**Registered organisation e-mail**	[redacted]

Test ID	Test Date	Source Room	Receiving Room	Project Type	Wall / Floor	Type	Target	Descriptor	Result	Pass / Fail †	Retest Comments
1	17/04/2023	No8 GF commercial unit (cake shop)	First Floor Flat living area	HFCON	Floor	New Test	≥ 43 dB	$D_{nT,w} + C_{tr}$	52 dB	✓	New Test
2	17/04/2023	No8 GF commercial unit (cake shop)	First Floor Flat kitchen	HFCON	Floor	New Test	≥ 43 dB	$D_{nT,w} + C_{tr}$	54 dB	✓	New Test

HFNB - Purpose built houses and flats
HFCON - Houses and flats formed by material change of use
RRNB - Purpose built rooms for residential purposes
RRCON - Rooms for residential purposes formed by material change of use

✓ Performance at or better than the performance standard cited in Building Regulations Approved Document E
✕ Performance is worse than the performance standard cited in Building Regulations Approved Document E
† *Responsibility for deciding on compliance with Building Regulations lies with the Building Control Body*
H Historic Building – Result should be displayed in a conspicuous place inside the building in accordance with Regulation 1 or 20(1) and (5) – ADE ref Section 0.7

[redacted]

This Certificate confirms that the tests described in the list above gave the results stated and were carried out by the named ANC registered test organisation, at the stated property, on the stated date and that the named test organisation was a member of the ANC Scheme at the time of the tests.