From: Lee.Money <Lee.Money@horsham.gov.uk>
Sent: 17 June 2025 15:32:13 UTC+01:00
To: "Kate.Turner" <Kate.Turner@horsham.gov.uk>
Subject: RE: Planning Application Consultation - DISC/25/0169 Sluetts Farm Buildings Two Mile Ash EH response

Hi Kate

Thanks for the consultation request.

The water neutrality statement provided with DC/23/0306 details the installation of rainwater harvesting system to provide water for livestock and washing down. This system is off-setting the water used to supply the agricultural workers dwelling. As the system is not being used to provide drinking water or water for sanitary purposes it does not come within the Private Water Supply regulations.

If you are happy with offsetting arrangements then the condition can be discharged.

Regards

Lee

Lee Money

Team Leader Pollution

Telephone: 01403 215410 | 07879 481032
Email: Lee.Money@horsham.gov.uk

Horsham District Council

Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

---

From: Planning <planning@horsham.gov.uk>
Sent: 16 June 2025 09:31
To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>; Gareth.Jones <Gareth.Jones@horsham.gov.uk>
Subject: Planning Application Consultation - DISC/25/0169

Please see the attached consultation letter from Horsham District Council
Re:DISC/25/0169

Telephone:
Email: planning@horsham.gov.uk



Horsham District Council

Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton