

# Tree Survey and Impact Assessment

*for land west of  
Ravenscroft  
Storrington*

Client  
A2 Dominion Housing Group Ltd

August 2026

**1452-KC-XX-YTREE-TreeSurvey-and-ImpactAssessment-RevA**

The Studio, Timbers, Gables Road, Church Crookham, Fleet, Hampshire, GU52 6QY  
Telephone +44(0)1252 850096 | Email: mail@keenconsultants.co.uk

Keen Consultants is a trading name of Keen (Europe) Limited. Registered No. 12641584  
Registered office: 4 Sudley Road, Bognor Regis, West Sussex, PO21 1EU

**KEEN**  
  
**CONSULTANTS**

© Keen Consultants

*The copyright of this document resides with Keen Consultants unless assigned in writing by the company.*

#### Document history

| Revision | Issue Status | Details                                                      | Approved/Date         |
|----------|--------------|--------------------------------------------------------------|-----------------------|
| Rev0     | Final        | Initial combined Tree Survey and Impact Assessment           | JK / 10 November 2020 |
| RevA     | Final        | Updated Tree Survey and Impact Assessment for RM submission. | JK / 26 August 2026   |

## Contents

|     |                                               |    |
|-----|-----------------------------------------------|----|
| 1.0 | Introduction.....                             | 4  |
| 2.0 | Tree survey .....                             | 6  |
| 3.0 | Application of survey information.....        | 7  |
| 4.0 | Assessment of impact upon trees .....         | 8  |
| 5.0 | New and replacement tree planting .....       | 10 |
| 6.0 | Protection of trees during construction ..... | 11 |
| 7.0 | Summary of impact assessment .....            | 11 |

## Tables

|                                                                               |          |
|-------------------------------------------------------------------------------|----------|
| <i>Table 1 - List of drawings referred to in the impact assessment .....</i>  | <i>8</i> |
| <i>Table 2 - List of documents used to inform the impact assessment .....</i> | <i>8</i> |

## Appendices

- Appendix 1 - Introduction to key elements of tree information
- Appendix 2 - Tree Survey Explanatory Notes
- Appendix 3 - Schedule of Trees

## 1.0 Introduction

1.1 This report sets out the information about trees to inform the planning process about the quality of trees on site. Following the tree survey the information is extended to consider the impact to them from the proposed development and how construction may proceed whilst ensuring trees are successfully retained.

1.2 In this report we consider the proposals for development of the site. We consider those proposals in relation to the survey of trees we conducted as part of the site analysis. The application proposals consist of:

*Reserved Matters Submission comprising: Layout; Landscaping; Scale; and, Appearance pursuant to Hybrid Consent (References: DC/21/2086 and SDNP/21/04702/OUT)*

1.3 The area subject of this survey consists of a parcel of land situated to the east of Greyfriars Lane, Storrington.

1.4 At the northern end the site consists of the Ravenscroft allotments that abut Ravenscroft to the east.

1.5 To the south the site consists of a collection of pasture fields that appear to have received little management in recent years.

1.6 Given the nature of land use there are few trees within the core of the site with trees contained around the boundaries and divisions between fields.

1.7 The land within the southern half of the site contains a number of large mature oak trees, some of which would be classed as veteran.

1.8 Along Greyfriars Lane is a dense hedgerow although this becomes more sparse south of the equipment compound.

1.9 It is noticeable that the ash trees on the site are suffering from Ash Dieback.

- 1.10 Within the field immediately south of the allotments is a large dead oak tree. It is decayed at the base and has become fragile. Its ecological value could be retained but relocated within open space within the future development.
- 1.11 We have checked the online portal of Horsham District Council for statutory protection of trees applicable to the site. Online portals are not always reliable so before works are undertaken to trees a direct enquiry with the Council should be made.
- **TREE PRESERVATION ORDERS** - details were available online and showed that there are NO Tree Preservation Orders protecting trees upon the site.
  - **CONSERVATION AREAS** - details were available online and confirmed that the site IS NOT within the Conservation Area but lies just outside its western edge.
- 1.12 Nationally adopted guidance has been followed in the preparation of this report. *BS5837:2012: Trees in relation to design, demolition and construction – Recommendations* sets out a structure approach to considering trees during the development process. Guidance is given on the surveying of trees, the protected space that should be allocated to trees, what elements may give rise to harm to trees and what techniques can be deployed to minimise harm.
- 1.13 Sustainable development requires the coordination between disciplines throughout the project, accordingly the package of arboricultural information supports the design process and follows through to construction ensuring effective tree protection. We recognise the need to integrate with other disciplines to achieve a balanced approach to development proposals.
- 1.14 We set out how our key elements interact with others at Appendix 1 of this report. The appendix provides comprehensive information about the stages of providing tree information within the planning process.
- 1.15 Further explanatory notes about tree survey information are given in Appendix 2.

## 2.0 Tree survey

- 2.1 The objective of this tree survey is to assess the significant trees and woody vegetation on the site to obtain dimensions, assess their quality and evaluate their condition to provide sufficient information to enable decisions to be made on planning aspects of the site and its potential development.
- 2.2 The tree survey:
  - 2.2.1 was conducted on the 10 June 2020 by Jago Keen, MSc, Dip.Arb., MArborA, MICFor from ground level, in accordance with the guidance in British Standard *BS5837:2012 Trees in relation to design, demolition and construction – Recommendations*;
  - 2.2.2 is intended for planning purposes only;
  - 2.2.3 is not intended for the detailed design of foundations (further information upon vegetation can be provided upon request);
  - 2.2.4 is not a detailed health and safety condition survey of trees;
  - 2.2.5 recommends only preliminary works. Tree works required to achieve the scheme of development will be considered as part of the Impact Assessment and detailed on the Tree Protection Plan;
  - 2.2.6 places reliance on the topographical survey.
- 2.3 Details of each tree are recorded in the Schedule of Trees at Appendix 3.
- 2.4 Site soil investigations have not been conducted. The (online) 'Geology of Britain Viewer' that contains British Geological Survey materials © NERC [2018] reveals the following soil information:
  - 2.4.1 Bedrock geology: Lower Greensand Group - Sandstone and mudstone.
  - 2.4.2 Superficial deposits: None recorded.

- 2.5 Survey information is used to prepare the constraints posed by trees on development. These constraints are shown on the Tree Constraints Plan. The Plan shows root protection areas prescribed by the guidance within BS5837 paragraph 4.6.2 and adjusted where appropriate as recommended in subsequent paragraph 4.6.3. The root protection area (RPA) is the minimum extent of rooting required to sustain the tree.

### 3.0 Application of survey information

- 3.1 Trees place constraints on sites but they also provide opportunities in order to achieve optimum use of the site and location of built structures. This is set out below:

#### Avoid

The starting point of site layout design should be to avoid the RPA. Ideally, structures should be outside the root protection area to provide working space for construction however protection measures can be taken if such clearance, in isolated cases, is not achievable.

#### Mitigate

Where intrusion within the RPA is unavoidable then its impact on the tree can be mitigated by specialist measures:

- a) Foundations that avoid trenching e.g. screw piles, suspended floor slabs or casting at ground level for lightweight structures such as bin and cycle stores.
- b) Limited use may be made for parking, drives or hard surfaces within the root protection areas, subject to advice from a qualified arboriculturist. Cellular confinement systems that enable hard surfaces to be built above existing soil levels are acceptable methods.
- c) Service runs that cannot be routed outside the root protection area(s) can be installed by, for example, thrust boring, directional drilling, air excavation or hand digging. These operations often require supervision by the project arboriculturist.

#### Compensate

Replacement planting can ensure the continuity of tree cover where tree removal is unavoidable. Offsite provision may be considered in some circumstances but this will require negotiation with the local planning authority.

## 4.0 Assessment of impact upon trees

- 4.1 This assessment will consider the impact upon trees of implementing the proposals shown on the drawings listed below:

*Table 1 - List of drawings referred to in the impact assessment*

| Originator       | Drg No                               | Title                 |
|------------------|--------------------------------------|-----------------------|
| HNW Architects   | 26025-HNW-ZZ-ZZ-DR-A-2100<br>Rev P05 | Proposed Site Plan    |
| Keen Consultants | 1452-KC-XX-YTREE-TCP01Rev0           | Tree Constraints Plan |
| Keen Consultants | 1452-KC-XX-YTREE-TPP02Rev0           | Tree Protection Plan  |

- 4.2 Site proposals considered in this application include:

4.2.1 Residential dwellings

4.2.2 Access, parking and other hard surfaces

4.2.3 Utilities and services

4.2.4 New and replacement tree planting

- 4.3 The proposals are considered with reference to the following guidance documents referred to in this report:

*Table 2 - List of documents used to inform the impact assessment*

| Originator                                      | Title/Reference                                                                               |
|-------------------------------------------------|-----------------------------------------------------------------------------------------------|
| British Standards Institute                     | <i>BS5837:2012 Trees in relation to design, demolition and construction – Recommendations</i> |
| Trees and Design Action Group                   | <i>Trees in the townscape: A guide for decision makers</i>                                    |
| Department for Communities and Local Government | <i>National Planning Policy Framework (NPPF) (August 2026)</i>                                |

- 4.4 National planning policy (DP3, N2, N3 and N6 of the NPPF) makes clear the important contribution made by trees to the character and quality of built environments, and their role to mitigate and adapt to climate change. The application proposals are respectful of the benefits trees provide and have been developed to ensure the retention of trees and the incorporation of new trees within the layout.
- 4.5 In summary, the proposals seek to conserve and maintain all significant trees and are located remote from root protection areas. New tree planting is proposed to enhance local tree cover.

#### *Impact of proposed site layout*

- 4.6 The proposed site layout follows the principles set out in the outline application and is accommodated within the current allotment area and field immediately to the south.
- 4.7 All significant trees (excluding those removed to make way for the access from Ravenscroft and discussed below) are retained and safeguarded by the scheme of development.
- 4.8 Generous separation is afforded to the trees that lie along the western boundary. The proposed ecological buffer along this boundary also ensures the trees are retained remote from individual properties. This ensures a harmonious relationship between the properties and the trees.
- 4.9 The layout demonstrates that the high quality trees in the south east of the parcel are retained successfully. These English oak trees, numbers 23 to 25, are visually significant trees of merit and they are retained within an area of open space ensuring they can be enjoyed as they mature.
- 4.10 The arrangement of buildings has sought generous separation from trees on the eastern boundary. All built-form is sited outside the root protection areas of retained trees to ensure they can flourish in future years.
- 4.11 It is necessary to remove a low quality hedgerow and low quality trees; trees 40-46 and 71 to 74 are to be removed. None of these are of sufficient merit that they should constrain a scheme of development and their loss can be offset by new planting within the layout of housing and within the proposed community parkland.

- 4.12 A dead oak stump, number 33, is to be relocated within the community parkland to the south of the indicative layout of development to ensure its value as an ecological resource is retained nearby.

#### *Impact of access arrangement*

- 4.13 The access arrangements were approved as part of the outline planning consent.
- 4.14 The northern access from Ravenscroft continues to require the removal of two moderate quality trees, numbers 7 and 8. Both are field maple. Their loss is necessary to achieve the access and, by removing these lesser trees, the more significant trees on the Ravenscroft boundary are retained.
- 4.15 The southern access from Ravenscroft also requires tree removal. Trees 12, 13 and 14 are to be removed. Tree 12 is a compromised English oak that has developed poorly. Tree 13 is an ash suffering ash dieback. Tree 14 is a moderate quality English oak. It is of some stature but is close to the adjoining residential property and dominates the garden. The loss of these trees is directly necessary to achieve the access in this location.

#### *Impact of drainage and services*

- 4.16 The proposed drainage and services are not shown on the application proposals but there is ample scope to locate them outside of root protection areas and require no specialist measures for their installation.
- 4.17 If services do need to be installed within root protection areas then specialist techniques for their installation will be needed. Such specialist techniques include moling, thrust-boring, broken trench or excavation by AirSpade.

## **5.0 New and replacement tree planting**

- 5.1 As touched on above, the development proposals bring forward opportunity to plant a selection of trees throughout the development. New tree planting can be incorporated within the detailed layout of housing as and when it comes forward, the allotment proposals secure new tree and hedge planting and so does the proposed community park. Read in conjunction with the low number of trees being removed the result is a net gain in tree cover and contribution to landscape.

- 5.2 Retaining existing trees and introducing new trees ensures a resource of trees in places where residents and visitors alike will enjoy multiple benefits provided by the tree stock. In so doing the tree stock will be able to withstand climate change, protecting and enhancing the resources of soil, air, water, landscape, amenity value, culture and biodiversity, and increasing the contribution that trees make to the quality of life. In that respect the proposals are in line with the very latest guidance, in terms of integrating trees with built form, contained in *Trees in the townscape: A guide for decision makers* produced by the Trees and Design Action Group and the requirement of DP3, N2 and N3 of the *National Planning Policy Framework*.
- 5.3 Those multiple benefits of this new tree planting, as part of the site's green infrastructure, include contribution to open space, enhancement of sustainable drainage systems, and enhancement of biodiversity. In addition, as those new trees develop, so they will further contribute to local climatic regulation and, where they stand within the sun path of proposed buildings or surfaces within the re-development, they will minimise solar gain during summer months, and provide an accessible choice of shade and shelter.

## 6.0 Protection of trees during construction

- 6.1 To ensure the retained trees are safeguarded a tree protection plan has been prepared to show the location of protective measures. These measures need to be implemented in advance of construction and maintained until such time as soft landscape proposals require their removal.

## 7.0 Summary of impact assessment

- 7.1 The proposed development results in the loss of very few trees, most of which are low quality and value.
- 7.2 Careful and considerate design has resulted in significant trees being retained and afforded space to ensure they are safeguarded.
- 7.3 Services and utility installation can be sited remote from trees as part of the detailed layout design but if they do need to be located within root protection areas specialist measures can be deployed for their installation to minimise harm to retained trees.
- 7.4 Substantial new tree planting is provided as part of these development proposals. This new cohort of trees can provide a diverse portfolio of tree cover to ensure sustainability of green infrastructure in the future.

- 7.5 The application proposals recognise the important contribution trees make to the character and quality of built environments, and the role they play to help mitigate and adapt to climate change. The proposals seek to retain existing trees and integrate new trees in accordance with the requirement of local and national planning policy.

# Appendix 1

Introduction to key elements of tree information

Sustainable development requires the coordination between disciplines throughout the project, accordingly the package of arboricultural information supports the design process and follows through to construction ensuring effective tree protection.

Keen Consultants break the process down to coordinate with the key elements within both the RIBA Plan of Work (2013) and 'British Standard 5837:2012 Trees in relation to design, demolition and construction – Recommendations', this is set out in the table and explained below.

**Figure 1 - Keen Consultants co-ordinated approach with cross references to key guidance.**

| Keen Consultants<br>Tree Information | RIBA Stage            | BS5837                         |
|--------------------------------------|-----------------------|--------------------------------|
| Tree Survey<br>↓                     | Concept<br>↓          | Feasibility<br>↓               |
| Impact Assessment<br>↓               | Developed design<br>↓ | Proposals<br>↓                 |
| Method Statement<br>↓                | Technical design<br>↓ | Technical Design<br>↓          |
| Site Monitoring                      | Construction          | Demolition<br>and construction |

This cross referenced approach ensures trees are a material consideration and those to be retained will be safeguarded.

## Tree Survey and Tree Constraints Plan

To inform the design and layout of the proposed development a tree survey has been undertaken to identify the size and quality of trees both within the site and immediately offsite. We have then used this information to prepare the Tree Constraints Plan drawing that shows the location of each tree, its size and the area around each tree that needs to be considered during the design process. Once prepared this information has been provided to the design team so that they know what constraints the trees pose.

## Impact Assessment and Tree Protection Plan

During the design process the design team has consulted with the arboriculturist to ascertain if constraints may be breached, consider options emerging from the design and what spaces for new trees are needed.

Once the design was finalised an impact assessment has been prepared to accompany the planning application. The impact assessment demonstrates the proposals meet national and local planning policy and guidance. It demonstrates the benefits of the retained trees and incorporates new tree planting.

Another essential element of any application is the Tree Protection Plan.

## **Method Statement**

This statement sets out in words how each element of work is undertaken in relation to the trees. It dictates when activities occur and the method that will be used to achieve them. It will also set out a scheme of monitoring and supervision.

## **Site Monitoring**

Following the receipt of planning consent, it is a requirement that the installation of the protective barriers and ground protection are supervised, together with operations such as excavations or surfacing close to trees.

This varies according to the intensity of development near trees, the process is set out to ensure what is planned for in the Tree Protection Plan and method statement is delivered.

# Appendix 2

## Tree Survey Explanatory Notes

The survey of trees has been carried out in accordance with the criteria set out in Chapter 4 of *British Standard 5837:2012 Trees in relation to design, demolition and construction-Recommendations* (BS5837). The survey has been undertaken by the qualified and experienced arboriculturist detailed at Table 1 of this report and they recorded information relating to all those trees within the site and those immediately adjacent to the site which may be of influence to any proposals.

The results are recorded in the Schedule of Trees at Appendix 3.

## **Schedule of trees**

Appendix 3 presents details of the individual trees, groups and hedgerows including heights, diameters at breast height, crown spread (given as a radial measurement of cardinal points from the stem), age class, comments as to the overall condition at the time of inspection, BS5837 category of quality and suitability for retention, and the root protection area information.

General observations particularly of structural and physiological condition for example the presence of any decay and physical defect and preliminary management recommendations have also been recorded where appropriate.

## **Details of the individual trees, groups and hedgerows**

All trees were assessed for their quality and benefits within the context of proposed development in a transparent, understandable and systematic way.

### **Individuals**

The default position is to record each tree as an individual for its unique contribution to the landscape

### **Groups and woodlands**

Trees have been assessed as groups where it has been determined appropriate by the surveyor. The term group has been applied where trees form cohesive arboricultural features either aerodynamically, visually or culturally.

### **Hedges and shrub masses**

We consider a hedgerow to typically comprise a line of trees or shrubs that currently is subject to, or has undergone, a pruning regime to contain its dimensions.

For the tree survey hedgerows and substantial internal or boundary hedges (including evergreen screens) have either been recorded in the Tree Schedule, including lateral spread, height and stem diameter(s), or indicated on the Tree Constraints Plan.

A tree survey in accordance with BS5837 does not assess hedgerows against *The Hedgerow Regulations 1997* or specifically from an ecological perspective, as such would be outside the scope of the British Standard assessment.

Shrub masses are collectives of woody plants, rather than trees, and are recorded where they are a significant feature of the site. They have either been recorded in the Tree Schedule or indicated on the Tree Constraints Plan.

## Individual trees within groups, woodlands and hedges

An assessment of individual trees within the groups has been made where there has been a clear need to differentiate between them for example, in order to highlight significant variation between attributes including physiological or structural condition or where a potential conflict may arise.

## BS5837 Categorisation

Trees have been divided into one of four categories based on Table 1 of BS5837, 'Cascade chart for tree quality assessment'. For a tree to qualify under any given category it should fall within the scope of that category's definition (see below).

Category U trees are those which would be lost in the short term for reasons connected with their physiology or structural condition. They are, for this reason not considered in the planning process on arboricultural grounds. Categories A, B & C are applied to trees that should be of material considerations in the development process. Each category also having one of three further sub-categories (i, ii, iii) which are intended to reflect arboricultural, landscape and cultural or conservation values accordingly.

Please note that the estimated remaining life expectancy figures are taken for BS5837 and relate to their categorisation. The life expectancy figures are therefore arbitrary and may vary in reality.

### Category (U)

Trees that have a serious irremediable structural defect such that their early loss is expected due to collapse and includes trees that will become unviable after removal of other category U trees.

Trees that are dead or are showing signs of significant, immediate or irreversible overall decline.

Trees that are infected with pathogens of significance to the health and/ or safety of other nearby trees or are very low quality trees suppressing adjacent trees of better quality.

Certain category U trees can have existing or potential conservation value which may make it desirable to preserve.

### Category (A)

Shown green on Tree Constraints Plan: Trees that are considered for retention and are of high quality with an estimated remaining life expectancy of at least 40 years and with potential to make a lasting contribution. Such trees may comprise:

### Sub categories

- 1) trees that are particularly good examples of their species, especially if rare or unusual, or are essential components of groups such as formal or semi-formal arboricultural features for example the dominant and/or principal trees within an avenue.
- 2) trees, groups or woodlands of particular visual importance as arboricultural and/or landscape features.
- 3) trees, groups or woodlands of significant conservation, historical, commemorative or other value for example veteran or wood pasture.

## Category (B)

Shown blue on Tree Constraints Plan: Trees that are considered for retention and are of moderate quality with an estimated remaining life expectancy of at least 20 years and with potential to make a significant contribution. Such trees may comprise:

### Sub categories

- 1) trees that might be included in category A but are downgraded because of impaired condition for example the presence of significant though remediable defects, including unsympathetic past management and storm damage.
- 2) trees present in numbers, usually growing as groups or woodlands, such that they attract a higher collective rating than they might as individuals or trees occurring as collectives but situated so as to make little visual contribution to the wider locality.
- 3) trees with material conservation or other cultural value.

## Category (C)

Shown grey on Tree Constraints Plan: Trees that are considered for retention and are of low quality with an estimated remaining life expectancy of at least 10 years or young trees with a stem diameter below 150mm. Such trees may comprise:

### Sub categories

- 1) unremarkable trees of very limited merit or such impaired condition that they do not qualify in higher categories.
- 2) trees present in groups or woodlands, but without this conferring on them significantly greater collective landscape value or trees offering low or only temporary/transient screening benefits.
- 3) trees with no material conservation or other cultural value.

## Devising BS5837 root protection areas

### Default situation

The root protection area is a function of the stem diameter, it is multiplied by 12 to give a radius. For multi-stemmed trees the stems are combined to provide an effective diameter figure which is then multiplied.

Initially the root protection area should be plotted as a circle, and in many situation it remains a circle.

### Influenced situation

Adjustments to the root protection area are made where pre-existing site conditions that would influence root distribution are present. Typically this will be buildings and retaining walls, lighter structures such as hard surfacing, sheds and garages generally do not have the same influence.

Ponds, rivers and watercourses will also influence root distribution as waterlogged soils are not conducive to root growth. Rainwater attenuation and ditches are likely to have a lesser impact if they are dry for significant periods.

## Veteran trees

Natural England have introduced Standing Guidance that requires the allocation of buffer zones to veteran (including ancient) trees. They have prescribed that a buffer zone of 15 times the stem diameter of the tree is allocated. This will result in a buffer zone of larger diameter than the root protection area. Where veteran trees are identified during the tree survey they are allocated a Natural England buffer zone on the Tree Constraints Plan.

The Guidance is silent on what can and cannot be done within the buffer zone but it is reasonable to assume that it is prescribed to avoid material harm to the tree. It is also silent on what can and cannot be done when the land within the buffer zone is previously developed.

With this added layer of protection it is important to establish if a tree is veteran or not. The Guidance was not intended to be applied to all mature trees but to the sub-set of trees that are of great age. This is analogous with the NPPF requirement to safeguard trees that have attained an age where they are worthy of veteran or ancient status.

It is therefore important to establish a basis for defining trees as veteran as opposed to those trees that may have veteran characteristics or those trees that are mature.

Stem size is a useful guide and, in combination with size, so are characteristics of the tree. If we consider the guidance on stem size being a suitable guide to classifying trees as veteran we see:

- a) The most up to date (2013) guidance is that in <sup>1</sup>*Ancient and other veteran trees: further guidance on management* edited by David Lonsdale and published by The Tree Council in conjunction with The Ancient Tree Forum. Lonsdale considers that many trees may have veteran characteristics at any age however proposes, at a species level, size thresholds when a tree may be considered a veteran. A chart (see Figure 1 below) lists, species by species, the size criteria for trees reaching veteran status and then moving on to the later, ancient stage of life. Of those species listed in the chart we only need consider oak. We see that until trees attain a stem girth of around 4.6m (equivalent stem diameter of 1.46m) then an oak is only considered to be 'Locally notable'
- b) A somewhat older (1999) publication, <sup>2</sup>*Veteran Trees: A guide to good management* edited by Helen Read and published by English Nature et al, is very similar in its definition by setting out three distinct bands for oak trees:
  - i) those with a diameter of more than 1.0m are potentially interesting
  - ii) those with a diameter of more than 1.5m are valuable in terms of conservation
  - iii) those over 2.0m in diameter are truly ancient
- c) English Nature's own <sup>3</sup>*Development of a veteran tree site assessment protocol (Report Number 628)* of 2005 sought to give more structure to grading sites where veteran trees were present. It considered that trees over 1.0m diameter could be classed as veteran.

---

<sup>1</sup> *Ancient and other veteran trees: further guidance on management* edited by David Lonsdale and published by The Tree Council in conjunction with The Ancient Tree Forum

<sup>2</sup> *Veteran Trees: A guide to good management* edited by Helen Read and published by English Nature et al

<sup>3</sup> *Development of a veteran tree site assessment protocol (Report Number 628)* of 2005

In summary, a tree may enter its veteran stage at 1.0m diameter but a more reliable size threshold, as held out by the latest guidance on the matter, is 1.5m diameter.

The other factor, tree characteristics, is also worth considering as veteran tree characteristics can be found on even young trees. Of course, if we count every tree with veteran tree characteristics as veteran we do a disservice to those truly veteran trees that warrant protection.

Read (1999), as set out above, considers veteran tree characteristics as:

- large girth for species
- major trunk cavities or progressive hollowing
- naturally forming water pools
- decay hollows
- physical damage to trunk
- bark loss
- large quantities of deadwood within the crown
- sap runs
- crevices in the bark, under branches or on the root plate sheltered from direct rainfall
- fungal fruiting bodies
- high number of interdependent wildlife species
- epiphytic plants
- an 'old' look
- high aesthetic interest

Lonsdale (2013) adds to this list:

- progressive narrowing of successive annual increments in the stem
- changes in crown architecture
- progressive or episodic reduction in post-mature crown size, often known as retrenchment

Lonsdale also states that "In order to qualify as a veteran, the tree should show signs of crown retrenchment and signs of decay in the trunk, branches or roots, such as exposed deadwood or fungal fruit bodies".

The English Nature Report Number 628 refers to Read (1999) for a list of veteran features but does add that in addition a tree may also:

- have a pollard form or show indications of past management
- have a cultural/historic value
- be in a prominent position in the landscape

These three criteria, when examined, are not truly indicative of a veteran tree on their own as these criteria could be applied to street trees in peri-urban locations that date from the mid-20th century - many of those are of pollard form, have cultural and historic value and a prominent position in the landscape.

In summary, it is important to consider the size of the tree and its characteristics. Just because a tree is mature does not mean it is veteran neither does the presence of veteran characteristics alone.




Figure 1- Chart of girth in relation to age and developmental classification of trees

# Appendix 3

## Schedule of Trees

*for land at  
Ravenscroft  
Storrington*

## Key to Tree Schedule

| Column Heading                                                                                        | Explanation                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
|-------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Tree No.                                                                                              | Unique number corresponding with number on plan                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |
| Species                                                                                               | English names                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |
| Ht (m)                                                                                                | Height in metres                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |
| Branch Spread                                                                                         | Crown radius in metres to cardinal points of the compass                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |
| Stem diameters (cm)                                                                                   | All measurements conform to Annex C of BS 5837:2012<br>Single stem - Stem diameter in centimetres measured at 1.5m above ground level.<br>Multi-stemmed tree with 2 to 5 stems – Diameter of each stem<br>Multi-stemmed tree with more than 5 stems – Average stem diameter and number of stems                                                                                                                                                                                                                                                                                                                                                          |
| Height of crown clearance                                                                             | Height in metres between the ground and underside of canopy                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
| Height of first major branch and direction of growth                                                  | Height from ground level to base of first major branch and the approximate direction of growth                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| Abbreviations as suffix to a dimension                                                                | <i>Suffix 'e' denotes an estimated dimension.</i><br><i>Suffix 'av' denotes an average dimension</i>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| Age class                                                                                             | Age Class definitions:<br>Y = Young<br>S = Semi-mature<br>E = Early mature<br>M = Mature<br>O = Over mature                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
| Category grading (see Appendix 2 for detailed explanation) and Estimated remaining contribution (yrs) | Summary of BS 5837: 2012 categorisation:<br>1. Trees that do not warrant consideration for retention:<br>U = those in such a condition that any existing value would be lost within 10 years and which should, in the current context, be removed for reasons of sound arboricultural management.<br>2. Trees to be considered for retention:<br>A1, 2 or 3 = trees of high quality and value (substantial contribution >40 yrs)<br>B1, 2 or 3 = trees of moderate quality and value (significant Contribution >20 yrs)<br>C1, 2 or 3 = trees of low quality and value (but adequate, ie >10 yrs or young trees – until new planting can be established) |
| Estimated remaining contribution                                                                      | Useful estimated remaining contribution of the tree or tree group                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Condition                                                                                             | Brief description including physiological and structural defects                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |
| Preliminary management recommendations                                                                | Describes current arboricultural requirement for the tree in its current context and should be undertaken as soon as reasonably practicable.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |
| Root protection radius                                                                                | Radius of minimum root protection area in metres calculated from section 4.6 and Annex D of BS5837:2012                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| Root protection area                                                                                  | Total area of minimum root protection area extrapolated from root protection radius                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |

## Schedule of trees on land west of Ravenscroft, Storrington

| Tree No. | Species                  | Ht (m) | Branch Spread (m) |   |   |   | Stem diameters (cm) |           |        |        |        |        |                   | Height of crown clearance (m) | Height of first branch (m) and direction (compass point) | Age class | Category grading | Estimated remaining contribution (yrs) | Condition Physiological / Structural | Tree Works to BS3998                                                                                                                                                                                        | Root protection radius (m) | Root protection area sq.m |           |
|----------|--------------------------|--------|-------------------|---|---|---|---------------------|-----------|--------|--------|--------|--------|-------------------|-------------------------------|----------------------------------------------------------|-----------|------------------|----------------------------------------|--------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------|---------------------------|-----------|
|          |                          |        |                   |   |   |   | Single Stem         | 2-5 stems |        |        |        |        | More than 5 stems |                               |                                                          |           |                  |                                        |                                      |                                                                                                                                                                                                             |                            |                           |           |
|          |                          |        | N                 | E | S | W |                     | Stem 1    | Stem 2 | Stem 3 | Stem 4 | Stem 5 | Mean dia          |                               |                                                          |           |                  |                                        |                                      |                                                                                                                                                                                                             |                            |                           | No. stems |
| 1        | Mixed broadleaf hedgerow | 2av    | 1av               |   |   |   | 10av                |           |        |        |        |        |                   |                               | 0                                                        | -         | S                | B2                                     | >20                                  | Established hedgerow growing along footpath. Species include hawthorn, blackthorn and hazel.                                                                                                                |                            | 1.20                      | 5         |
| 2        | Ash                      | 14     | 5                 | 6 | 6 | 6 | 60e                 |           |        |        |        |        |                   |                               | 3                                                        | 3S        | E                | C1                                     | >10                                  | Established tree growing in hedgerow, Main stem and much of crown smothered in ivy. Showing early signs of Ash Dieback.                                                                                     |                            | 7.20                      | 163       |
| 3        | English oak              | 14     | 5                 | 6 | 6 | 4 | 50e                 |           |        |        |        |        |                   |                               | 4                                                        | 4S        | E                | C1                                     | >10                                  | Established tree growing in property adjoining footpath. Appears to have been crown reduced in the past.                                                                                                    |                            | 6.00                      | 113       |
| 4        | Lawson cypress           | 14     | 4                 | 4 | 4 | 4 | 45e                 |           |        |        |        |        |                   |                               | 2                                                        | 2S        | E                | C1                                     | >10                                  | Development compromised by adjoining oak.                                                                                                                                                                   |                            | 5.40                      | 92        |
| 5        | Ash                      | 14     | 7                 | 6 | 7 | 6 | 95e                 |           |        |        |        |        |                   |                               | 2                                                        | 2S        | E                | B1                                     | >20                                  | Old, established hedgerow tree. Some damage to buttress roots as a result of access to allotment gate. Triple-stemmed from 1.5 metres above ground level. Will likely succumb to Ash Dieback in the future. |                            | 11.40                     | 408       |
| 6        | Mixed broadleaf hedgerow | 2av    | 1av               |   |   |   | 10av                |           |        |        |        |        |                   |                               | 0                                                        | -         | S                | B2                                     | >20                                  | Established hedgerow alongside Ravenscroft. Species include blackthorn, dogwood, holly, field maple, hazel, hawthorn and privet. Likely to be of planted origin given the number of species.                | Remove section as shown.   | 1.20                      | 5         |
| 7        | Field maple              | 12     | 6                 | 4 | 0 | 5 | 40e                 |           |        |        |        |        |                   |                               | 2                                                        | 2N        | E                | B2                                     | >20                                  | Forms a contiguous crown with its neighbour. Main stem covered in ivy.                                                                                                                                      | Remove.                    | 4.80                      | 72        |
| 8        | Field maple              | 14     | 3                 | 6 | 7 | 7 |                     | 35e       | 35e    | 35e    | 35e    |        |                   |                               | 2                                                        | 3W        | E                | B2                                     | >20                                  | Forms a contiguous crown with its neighbour. Main stem covered in ivy.                                                                                                                                      | Remove.                    | 8.40                      | 222       |
| 9        | English oak              | 15     | 6                 | 7 | 7 | 6 | 90e                 |           |        |        |        |        |                   |                               | 2                                                        | 2S        | E                | B1                                     | >20                                  | Broad-spreading tree growing alongside Ravenscroft. Growing within hedge so unable to inspect base.                                                                                                         |                            | 10.80                     | 366       |
| 10       | Silver birch             | 15     | 5                 | 6 | 7 | 7 |                     | 37        | 29     |        |        |        |                   |                               | 2                                                        | 2S        | E                | B1                                     | >20                                  | Twin-stemmed tree growing in lawn to east of Ravenscroft.                                                                                                                                                   |                            | 5.64                      | 100       |

## Schedule of trees on land west of Ravenscroft, Storrington

| Tree No. | Species                   | Ht (m) | Branch Spread (m) |   |    |   | Stem diameters (cm) |           |        |        |        |        |                   |           | Height of crown clearance (m) | Height of first branch (m) and direction (compass point) | Age class | Category grading | Estimated remaining contribution (yrs) | Condition Physiological / Structural                                                                                                                           | Tree Works to BS3998     | Root protection radius (m) | Root protection area sq.m |
|----------|---------------------------|--------|-------------------|---|----|---|---------------------|-----------|--------|--------|--------|--------|-------------------|-----------|-------------------------------|----------------------------------------------------------|-----------|------------------|----------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------|----------------------------|---------------------------|
|          |                           |        |                   |   |    |   | Single Stem         | 2-5 stems |        |        |        |        | More than 5 stems |           |                               |                                                          |           |                  |                                        |                                                                                                                                                                |                          |                            |                           |
|          |                           |        | N                 | E | S  | W |                     | Stem 1    | Stem 2 | Stem 3 | Stem 4 | Stem 5 | Mean dia          | No. stems |                               |                                                          |           |                  |                                        |                                                                                                                                                                |                          |                            |                           |
| 11       | Group of ash              | 13av   | 6av               |   |    |   | 45av                |           |        |        |        |        |                   |           | 2                             | 2.5E                                                     | E         | C2               | >10                                    | Collection of stems probably having been once part of a hedgerow. Numerous wounds associated with past branch loss. Early signs of infection with Ash Dieback. | Remove.                  | 5.40                       | 92                        |
| 12       | English oak               | 13     | 3                 | 6 | 5  | 6 | 37                  |           |        |        |        |        |                   |           | 3                             | 3S                                                       | S         | C1               | >10                                    | Small tree that is compromised in its development due to presence of others.                                                                                   | Remove.                  | 4.44                       | 62                        |
| 13       | Ash                       | 13     | 6                 | 7 | 7  | 2 | 42                  |           |        |        |        |        |                   |           | 2                             | 2S                                                       | E         | C1               | >10                                    | Established tree growing in lawn adjoining parking. Beginning to show signs of Ash Dieback.                                                                    | Remove.                  | 5.04                       | 80                        |
| 14       | English oak               | 17     | 6                 | 7 | 9  | 7 |                     | 55e       | 45e    |        |        |        |                   |           | 3                             | 3S                                                       | E         | B1               | >20                                    | Broad-spreading tree that appears to be twin-stemmed from ground level. Growing within adjoining property.                                                     | Remove.                  | 8.53                       | 228                       |
| 15       | Hornbeam                  | 14     | 7                 | 7 | 7  | 7 |                     |           |        |        |        |        | 25                | 10        | 1.2                           | 1.2N                                                     | E         | B1               | >20                                    | Established, broad-spreading tree of multiple stems growing in lawn adjoining Ravenscroft.                                                                     |                          | 9.49                       | 283                       |
| 16       | Mixed broadleaf hedgerow  | 3av    | 2av               |   |    |   | 10av                |           |        |        |        |        |                   |           | 0                             | -                                                        | S         | B2               | >20                                    | Established hedgerow growing alongside footpath. Species include blackthorn, hawthorn, holly and ash.                                                          | Remove section as shown. | 1.20                       | 5                         |
| 17       | English oak               | 12     | 4                 | 5 | 5  | 5 | 30e                 |           |        |        |        |        |                   |           | 2                             | 2W                                                       | S         | C1               | >10                                    | Small tree growing in hedgerow alongside footpath.                                                                                                             |                          | 3.60                       | 41                        |
| 18       | Sycamore                  | 14     | 4                 | 5 | 6  | 6 | 27                  |           |        |        |        |        |                   |           | 3                             | 3W                                                       | S         | C1               | >10                                    | Established tree growing within hedgerow alongside footpath.                                                                                                   |                          | 3.24                       | 33                        |
| 19       | English oak               | 13     | 6                 | 7 | 6  | 6 | 45e                 |           |        |        |        |        |                   |           | 4                             | 4E                                                       | S         | B1               | >20                                    | Established tree growing within gardens adjoining footpath.                                                                                                    |                          | 5.40                       | 92                        |
| 20       | English oak               | 18     | 6                 | 8 | 10 | 6 | 110e                |           |        |        |        |        |                   |           | 2                             | 2N                                                       | M         | A1&3             | >40                                    | Visually significant tree growing at corner of footpath. Broad-spreading crown. Main stem and much of crown smothered in ivy.                                  |                          | 13.20                      | 547                       |
| 21       | Mixed broadleaf tree belt | 10av   | 4av               |   |    |   | 15av                |           |        |        |        |        |                   |           | 0                             | -                                                        | S         | C2               | >10                                    | Outgrown belt of vegetation between fields. Species include ash, goat willow and field maple. Ash showing definite signs of Ash Dieback.                       |                          | 1.80                       | 10                        |

## Schedule of trees on land west of Ravenscroft, Storrington

| Tree No. | Species                   | Ht (m) | Branch Spread (m) |    |    |   | Stem diameters (cm) |           |        |        |        |        |                   | Height of crown clearance (m) | Height of first branch (m) and direction (compass point) | Age class | Category grading | Estimated remaining contribution (yrs) | Condition<br>Physiological / Structural | Tree Works to BS3998                                                                                                                                                                                                                                                                                                            | Root protection radius (m) | Root protection area sq.m |           |
|----------|---------------------------|--------|-------------------|----|----|---|---------------------|-----------|--------|--------|--------|--------|-------------------|-------------------------------|----------------------------------------------------------|-----------|------------------|----------------------------------------|-----------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------|---------------------------|-----------|
|          |                           |        |                   |    |    |   | Single Stem         | 2-5 stems |        |        |        |        | More than 5 stems |                               |                                                          |           |                  |                                        |                                         |                                                                                                                                                                                                                                                                                                                                 |                            |                           |           |
|          |                           |        | N                 | E  | S  | W |                     | Stem 1    | Stem 2 | Stem 3 | Stem 4 | Stem 5 | Mean dia          |                               |                                                          |           |                  |                                        |                                         |                                                                                                                                                                                                                                                                                                                                 |                            |                           | No. stems |
| 22       | Mixed broadleaf tree belt | 7av    | 3av               |    |    |   | 15av                |           |        |        |        |        |                   |                               | 0                                                        | -         | S                | C2                                     | >10                                     | Sparse tree belt growing along field boundary. Consists primarily of blackthorn, ash and field maple. Many ash dying due to Ash Dieback. Much of belt dominated by bramble.                                                                                                                                                     |                            | 1.80                      | 10        |
| 23       | English oak               | 18     | 11                | 10 | 9  | 6 | 103                 |           |        |        |        |        |                   |                               | 2                                                        | 2E        | M                | A1&3                                   | >40                                     | Contributes to group of similar sized oak trees in this part of the site. Prominent buttresses and some hollowing between indicative of typical pattern of decay associated with oaks at this age. Typically this decay does not affect the stability of the trees at this stage. Some large sections of deadwood within crown. |                            | 12.36                     | 480       |
| 24       | English oak               | 17     | 3                 | 6  | 10 | 3 | 100                 |           |        |        |        |        |                   |                               | 5                                                        | 5S        | M                | A1&3                                   | >40                                     | Contributes to group of similar sized oak trees in this part of the site. Prominent buttresses and some hollowing between indicative of typical pattern of decay associated with oaks at this age. Typically this decay does not affect the stability of the trees at this stage. Some large sections of deadwood within crown. |                            | 12.00                     | 452       |
| 25       | English oak               | 17     | 10                | 8  | 10 | 9 | 124                 |           |        |        |        |        |                   |                               | 1                                                        | 3NE       | M                | A1&3                                   | >40                                     | Contributes to group of similar sized oak trees in this part of the site. Prominent buttresses and some hollowing between indicative of typical pattern of decay associated with oaks at this age. Typically this decay does not affect the stability of the trees at this stage. Some large sections of deadwood within crown. |                            | 14.88                     | 696       |
| 26       | Mixed broadleaf hedgerow  | 3av    | 2av               |    |    |   | 10av                |           |        |        |        |        |                   |                               | 0                                                        | -         | S                | C2                                     | >10                                     | Established, but sparse, hedgerow growing at field boundary. Species include blackthorn, ash, field maple and occasional oak sapling. Ash within the row are dying due to Ash Dieback.                                                                                                                                          |                            | 1.20                      | 5         |

## Schedule of trees on land west of Ravenscroft, Storrington

| Tree No. | Species                   | Ht (m) | Branch Spread (m) |   |    |   | Stem diameters (cm) |           |        |        |        |        |                   |           | Height of crown clearance (m) | Height of first branch (m) and direction (compass point) | Age class | Category grading | Estimated remaining contribution (yrs) | Condition Physiological / Structural                                                                                                                                                                                                                    | Tree Works to BS3998 | Root protection radius (m) | Root protection area sq.m |
|----------|---------------------------|--------|-------------------|---|----|---|---------------------|-----------|--------|--------|--------|--------|-------------------|-----------|-------------------------------|----------------------------------------------------------|-----------|------------------|----------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------|----------------------------|---------------------------|
|          |                           |        |                   |   |    |   | Single Stem         | 2-5 stems |        |        |        |        | More than 5 stems |           |                               |                                                          |           |                  |                                        |                                                                                                                                                                                                                                                         |                      |                            |                           |
|          |                           |        | N                 | E | S  | W |                     | Stem 1    | Stem 2 | Stem 3 | Stem 4 | Stem 5 | Mean dia          | No. stems |                               |                                                          |           |                  |                                        |                                                                                                                                                                                                                                                         |                      |                            |                           |
| 27       | English oak               | 18     | 6                 | 8 | 8  | 8 | 110e                |           |        |        |        |        |                   |           | 2                             | 4SE                                                      | M         | B1&3             | >20                                    | Established tree growing beyond fenceline. Appears to be lacking vitality. Some large sections of deadwood within crown.                                                                                                                                |                      | 13.20                      | 547                       |
| 28       | Ash                       | 18     | 8                 | 9 | 10 | 8 | 85e                 |           |        |        |        |        |                   |           | 3                             | 3S                                                       | M         | B1               | >20                                    | Established tree growing beyond fenceline. Likely to succumb to Ash Dieback in future years.                                                                                                                                                            |                      | 10.20                      | 327                       |
| 29       | Group of sycamore and ash | 16av   | 6av               |   |    |   | 35av                |           |        |        |        |        |                   |           | 2                             | 2E                                                       | E         | B2               | >20                                    | Established group of trees growing just beyond fenceline. Offers screening between site and adjoining properties. Ash showing signs of Ash Dieback.                                                                                                     |                      | 4.20                       | 55                        |
| 30       | Pair of English oak       | 17av   | 8av               |   |    |   | 70av                |           |        |        |        |        |                   |           | 0                             | 3E                                                       | E         | B2               | >20                                    | Pair of close growing trees forming contiguous crown. Located beyond fenceline.                                                                                                                                                                         |                      | 8.40                       | 222                       |
| 31       | Sycamore                  | 8      | 4                 | 5 | 4  | 0 | 16                  |           |        |        |        |        |                   |           | 1                             | 1NE                                                      | S         | C1               | >10                                    | Small tree growing along fenceline. Suppressed by adjoining lime.                                                                                                                                                                                       |                      | 1.92                       | 12                        |
| 32       | Row of lime               | 18av   | 8av               |   |    |   | 70av                |           |        |        |        |        |                   |           | 0                             | -                                                        | M         | A2               | >40                                    | Visually significant and dense screen of foliage growing beyond fenceline.                                                                                                                                                                              |                      | 8.40                       | 222                       |
| 33       | English oak               | 16     |                   |   |    |   | 100e                |           |        |        |        |        |                   |           |                               |                                                          | M         | U                | <10                                    | Dead tree growing within field. Lower stem with advanced decay so structure liable to collapse. Unsited to retention within a scheme of development but ecological interest could be retained by relocating the dead sections within nearby open space. | Remove.              | 12.00                      | 452                       |
| 34       | Ash                       | 9      | 3                 | 4 | 4  | 0 | 15e                 |           |        |        |        |        |                   |           | 0                             | -                                                        | S         | C1               | >10                                    | Suppressed by adjoining limes. Showing advanced signs of Ash Dieback.                                                                                                                                                                                   |                      | 1.80                       | 10                        |
| 35       | Row of western red cedar  | 17av   | 4av               |   |    |   | 30av                |           |        |        |        |        |                   |           | 0                             | -                                                        | M         | B2               | >20                                    | Established row of conifers growing beyond fenceline. Offer evergreen screening between site and adjoining properties.                                                                                                                                  |                      | 3.60                       | 41                        |

## Schedule of trees on land west of Ravenscroft, Storrington

| Tree No. | Species                  | Ht (m) | Branch Spread (m) |    |    |    | Stem diameters (cm) |           |        |        |        |        |                   |           | Height of crown clearance (m) | Height of first branch (m) and direction (compass point) | Age class | Category grading | Estimated remaining contribution (yrs) | Condition Physiological / Structural                                                                                                                                                                                                                                                   | Tree Works to BS3998 | Root protection radius (m) | Root protection area sq.m |
|----------|--------------------------|--------|-------------------|----|----|----|---------------------|-----------|--------|--------|--------|--------|-------------------|-----------|-------------------------------|----------------------------------------------------------|-----------|------------------|----------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------|----------------------------|---------------------------|
|          |                          |        |                   |    |    |    | Single Stem         | 2-5 stems |        |        |        |        | More than 5 stems |           |                               |                                                          |           |                  |                                        |                                                                                                                                                                                                                                                                                        |                      |                            |                           |
|          |                          |        | N                 | E  | S  | W  |                     | Stem 1    | Stem 2 | Stem 3 | Stem 4 | Stem 5 | Mean dia          | No. stems |                               |                                                          |           |                  |                                        |                                                                                                                                                                                                                                                                                        |                      |                            |                           |
| 36       | English oak              | 18     | 10                | 12 | 10 | 11 | 120e                |           |        |        |        |        |                   |           | 3                             | 3NE                                                      | M         | B1&3             | >20                                    | Large, broad-spreading crown. Has suffered significant limb loss in the past. Extensive decay at those points. Some large sections of deadwood within crown. Crown reduction would promote regeneration and enable long-term retention of the tree by reducing its chances of failure. |                      | 14.40                      | 652                       |
| 37       | Mixed hedgerow           | 3av    | 1av               |    |    |    | 10av                |           |        |        |        |        |                   |           | 0                             | -                                                        | Y         | B2               | >20                                    | Recently established hedgerow growing beyond fenceline. Species include box, holly and Leyland cypress. Offers low level evergreen screening.                                                                                                                                          |                      | 1.20                       | 5                         |
| 38       | Scarlet oak              | 10     | 4                 | 4  | 4  | 4  |                     | 15e       | 15e    |        |        |        |                   |           | 1                             | 1N                                                       | Y         | B1               | >20                                    | Young tree of unusual species growing beyond fenceline.                                                                                                                                                                                                                                |                      | 2.55                       | 20                        |
| 39       | Elm                      | 9      | 2                 | 2  | 2  | 2  | 20e                 |           |        |        |        |        |                   |           | 0                             | -                                                        | Y         | U                | <10                                    | Dead.                                                                                                                                                                                                                                                                                  | Remove.              |                            |                           |
| 40       | Group of elm             | 9av    | 3av               |    |    |    | 15av                |           |        |        |        |        |                   |           | 0                             | -                                                        | S         | U                | <10                                    | Small group of trees growing at southern end of tree belt. Showing signs of Elm Disease. Unsited to long-term retention. Understorey of predominantly blackthorn.                                                                                                                      | Remove.              | 1.80                       | 10                        |
| 41       | Hawthorn                 | 6      | 3                 | 4  | 3  | 3  | 15e                 |           |        |        |        |        |                   |           | 1                             | 1S                                                       | S         | C1               | >10                                    | Small tree outgrown from hedgerow. Crown dominated by ivy.                                                                                                                                                                                                                             | Remove.              | 1.80                       | 10                        |
| 42       | Mixed broadleaf hedgerow | 1.2av  | 1av               |    |    |    | 5av                 |           |        |        |        |        |                   |           | 0                             | -                                                        | E         | C2               | >10                                    | Sparse hedgerow overgrown with bramble. Species include blackthorn and dogrose.                                                                                                                                                                                                        | Remove.              | 0.60                       | 1                         |
| 43       | Group of hawthorn        | 6av    | 3av               |    |    |    | 15av                |           |        |        |        |        |                   |           | 0                             | -                                                        | S         | C2               | >10                                    | Small trees growing out from hedgerow.                                                                                                                                                                                                                                                 | Remove.              | 1.80                       | 10                        |
| 44       | Group of hawthorn        | 6av    | 3av               |    |    |    | 15av                |           |        |        |        |        |                   |           | 0                             | -                                                        | S         | C2               | >10                                    | Small trees growing out from hedgerow.                                                                                                                                                                                                                                                 | Remove.              | 1.80                       | 10                        |
| 45       | Group of ash             | 10av   | 5av               |    |    |    | 25av                |           |        |        |        |        |                   |           | 2                             | 2S                                                       | S         | C2               | >10                                    | Group of trees growing amidst hedgerow. Showing early signs of Ash Dieback.                                                                                                                                                                                                            | Remove.              | 3.00                       | 28                        |
| 46       | Mixed broadleaf hedgerow | 3av    | 2av               |    |    |    | 10av                |           |        |        |        |        |                   |           | 0                             | -                                                        | S         | C2               | >10                                    | Section of slightly taller hedgerow at eastern end. Species include hawthorn, holly and goat willow.                                                                                                                                                                                   | Remove.              | 1.20                       | 5                         |

## Schedule of trees on land west of Ravenscroft, Storrington

| Tree No. | Species          | Ht<br>(m) | Branch Spread<br>(m) |    |   |   | Stem diameters (cm) |           |        |        |        |        |                         |           | Height of crown<br>clearance (m) | Height of first branch<br>(m) and direction<br>(compass point) | Age class | Category grading | Estimated remaining<br>contribution (yrs) | Condition<br>Physiological / Structural                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              | Tree Works to BS3998 | Root protection radius<br>(m) | Root protection area<br>sq.m |
|----------|------------------|-----------|----------------------|----|---|---|---------------------|-----------|--------|--------|--------|--------|-------------------------|-----------|----------------------------------|----------------------------------------------------------------|-----------|------------------|-------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------|-------------------------------|------------------------------|
|          |                  |           |                      |    |   |   | Single Stem         | 2-5 stems |        |        |        |        | More<br>than<br>5 stems |           |                                  |                                                                |           |                  |                                           |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |                      |                               |                              |
|          |                  |           | N                    | E  | S | W |                     | Stem 1    | Stem 2 | Stem 3 | Stem 4 | Stem 5 | Mean dia                | No. stems |                                  |                                                                |           |                  |                                           |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |                      |                               |                              |
| 47       | English oak      | 19        | 11                   | 11 | 9 | 7 | 153                 |           |        |        |        |        |                         |           | 1                                | 2S                                                             | M         | A1&3             | >40                                       | Visually significant, broad-spreading tree growing within field. Trees of this size are considered to be veteran and therefore guidance recommends additional precautions in relation to development. Crown has suffered some branch loss in the past, as is typical of trees at this age. Similarly there are some large sections of deadwood within the crown. Decaying fruit bodies of <i>Inonotus dryadeus</i> at circa 1 metre above ground level on northern side of main stem indicating internal decay that is typical of trees of this age. |                      | 15.00                         | 707                          |
| 57       | Mixed tree group | 12av      | 5av                  |    |   |   | 25av                |           |        |        |        |        |                         |           | 0                                | -                                                              | S         | C2               | >10                                       | Cluster of outgrown vegetation growing along ditchline. Species include English oak, goat willow, ash, sycamore, hawthorn and blackthorn. Careful selection of individual trees and cutting back of vegetation would be beneficial.                                                                                                                                                                                                                                                                                                                  |                      | 3.00                          | 28                           |
| 71       | English oak      | 11        | 4                    | 6  | 6 | 5 | 40e                 |           |        |        |        |        |                         |           | 2                                | 2N                                                             | S         | C1               | >10                                       | Small tree growing in corner of allotment site. Main stem and crown densely smothered in ivy.                                                                                                                                                                                                                                                                                                                                                                                                                                                        | Remove.              | 4.80                          | 72                           |
| 72       | Eucalyptus       | 16        | 5                    | 6  | 4 | 6 | 54                  |           |        |        |        |        |                         |           | 2                                | 2S                                                             | S         | C1               | >10                                       | Established tree in corner of allotment site. Incongruous to setting.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | Remove.              | 6.48                          | 132                          |
| 73       | Norway spruce    | 11        | 2                    | 2  | 2 | 2 | 21                  |           |        |        |        |        |                         |           | 0                                | -                                                              | S         | C1               | >10                                       | Small conifer growing in corner of allotment site.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | Remove.              | 2.52                          | 20                           |
| 74       | English oak      | 10        | 5                    | 5  | 5 | 4 | 29                  |           |        |        |        |        |                         |           | 2                                | 2N                                                             | S         | C1               | >10                                       | Small tree growing within allotment plot. Extensive squirrel damage.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | Remove.              | 3.48                          | 38                           |
| 75       | English oak      | 14        | 4                    | 6  | 7 | 7 | 55e                 |           |        |        |        |        |                         |           | 2                                | 2E                                                             | E         | B2               | >20                                       | Part of a row of similar sized trees growing along fenceline to western side of ditch. Main stem and crown covered in ivy.                                                                                                                                                                                                                                                                                                                                                                                                                           |                      | 6.60                          | 137                          |

## Schedule of trees on land west of Ravenscroft, Storrington

| Tree No. | Species               | Ht (m) | Branch Spread (m) |   |   |   | Stem diameters (cm) |           |        |        |        |        |                   |           | Height of crown clearance (m) | Height of first branch (m) and direction (compass point) | Age class | Category grading | Estimated remaining contribution (yrs) | Condition Physiological / Structural                                                                                       | Tree Works to BS3998 | Root protection radius (m) | Root protection area sq.m |
|----------|-----------------------|--------|-------------------|---|---|---|---------------------|-----------|--------|--------|--------|--------|-------------------|-----------|-------------------------------|----------------------------------------------------------|-----------|------------------|----------------------------------------|----------------------------------------------------------------------------------------------------------------------------|----------------------|----------------------------|---------------------------|
|          |                       |        |                   |   |   |   | Single Stem         | 2-5 stems |        |        |        |        | More than 5 stems |           |                               |                                                          |           |                  |                                        |                                                                                                                            |                      |                            |                           |
|          |                       |        | N                 | E | S | W |                     | Stem 1    | Stem 2 | Stem 3 | Stem 4 | Stem 5 | Mean dia          | No. stems |                               |                                                          |           |                  |                                        |                                                                                                                            |                      |                            |                           |
| 76       | English oak           | 17     | 6                 | 7 | 7 | 9 | 75e                 |           |        |        |        |        |                   |           | 2                             | 2E                                                       | E         | B2               | >20                                    | Part of a row of similar sized trees growing along fenceline to western side of ditch. Main stem and crown covered in ivy. |                      | 9.00                       | 255                       |
| 77       | Elm                   | 11     | 4                 | 5 | 4 | 1 | 20e                 |           |        |        |        |        |                   |           | 2                             | 2E                                                       | S         | U                | <10                                    | Small tree growing alongside ditch. Main stem covered in ivy. Likely to succumb to Elm Disease.                            | Remove.              | 2.40                       | 18                        |
| 78       | English oak           | 17     | 5                 | 7 | 6 | 7 | 70e                 |           |        |        |        |        |                   |           | 2                             | 5E                                                       | E         | B2               | >20                                    | Part of a row of similar sized trees growing along fenceline to western side of ditch. Main stem and crown covered in ivy. |                      | 8.40                       | 222                       |
| 79       | English oak           | 16     | 7                 | 8 | 7 | 9 | 70e                 |           |        |        |        |        |                   |           | 3                             | 3E                                                       | E         | B2               | >20                                    | Part of a row of similar sized trees growing along fenceline to western side of ditch. Main stem and crown covered in ivy. |                      | 8.40                       | 222                       |
| 80       | English oak           | 10     | 5                 | 6 | 6 | 5 |                     | 45e       | 45e    |        |        |        |                   |           | 2                             | 1S                                                       | E         | B2               | >20                                    | Part of a row of similar sized trees growing along fenceline to western side of ditch. Main stem and crown covered in ivy. |                      | 7.64                       | 183                       |
| 81       | Variegated box elder  | 7      | 4                 | 4 | 4 | 4 | 15e                 |           |        |        |        |        |                   |           | 2                             | 2N                                                       | S         | C1               | >10                                    | Small ornamental tree growing within garden to north of allotments.                                                        |                      | 1.80                       | 10                        |
| 82       | Ginkgo                | 5      | 2                 | 2 | 2 | 2 | 15e                 |           |        |        |        |        |                   |           | 2                             | 2E                                                       | S         | C1               | >10                                    | Small ornamental tree growing in adjoining garden to north of allotments.                                                  |                      | 1.80                       | 10                        |
| 83       | Norway spruce         | 11     | 4                 | 4 | 4 | 4 | 31                  |           |        |        |        |        |                   |           | 2                             | 2S                                                       | S         | C1               | >10                                    | Conifer growing along northern boundary of allotment site.                                                                 |                      | 3.72                       | 43                        |
| 84       | Norway spruce         | 11     | 3                 | 3 | 3 | 3 | 26                  |           |        |        |        |        |                   |           | 2                             | 2S                                                       | S         | C1               | >10                                    | Conifer growing along northern boundary of allotment site.                                                                 |                      | 3.12                       | 31                        |
| 85       | Corkscrew willow      | 6      | 1                 | 3 | 3 | 2 | 15e                 |           |        |        |        |        |                   |           | 2                             | 2S                                                       | S         | C1               | >10                                    | Small ornamental tree growing to north of allotment site.                                                                  |                      | 1.80                       | 10                        |
| 86       | Variegated tulip tree | 10     | 4                 | 4 | 4 | 4 | 20e                 |           |        |        |        |        |                   |           | 2                             | 2S                                                       | S         | B1               | >20                                    | Reasonably well formed tree growing in garden to north of allotment site.                                                  |                      | 2.40                       | 18                        |
| 87       | Paperbark birch       | 10     | 5                 | 5 | 5 | 5 | 25e                 |           |        |        |        |        |                   |           | 2                             | 2S                                                       | S         | B1               | >20                                    | Reasonably well formed tree growing in garden to north of allotment site.                                                  |                      | 3.00                       | 28                        |