From: [redacted]
Sent:
To:
Subject: RE: Planning Application Consultation - DC/24/1214 27 Standen Place EH response 221124

Hi Joshua

Thanks for the re-consultation. As discussed I would recommend that the application is approved subject following conditions:

- Within 6 months of the date of commissioning of the air source heat pump hereby approved the boundary screen as detailed in the application plans shall be fully installed and thereafter maintained for as long as the air source heat pump remains operational.

- Between 23:00 and 07:00 hours the air source heat pump shall operate in low reduced power (setback) mode.

Regards

Lee

Lee Money
Team Leader Environmental Protection
[redacted]
Lee Mone y
Team Leader Environmental Protection
[redacted]





Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton
[redacted]

