

[illegible]

| Formula symbol |
|----------------|
| LWA5           |
| LWA6           |
| LWA2           |

| Reference | Model      | Air Flow<br>Vol. $\dot{V}_E$ | Pressure<br>Drop (Pa) | Weight | Material | Static mechanical loss (BSI at Culture Band Center Frequency) |        |        |        |         |         |         |         |
|-----------|------------|------------------------------|-----------------------|--------|----------|---------------------------------------------------------------|--------|--------|--------|---------|---------|---------|---------|
|           |            |                              |                       |        |          | 63 Hz                                                         | 125 Hz | 250 Hz | 500 Hz | 1000 Hz | 2000 Hz | 4000 Hz | 8000 Hz |
| ATT01     | RC2.5-1000 | 1.140                        | 20                    | 33.8g  | Yes      | 4                                                             | 7      | 12     | 20     | 21      | 22      | 16      | 14      |
| ATT02     | RC2.5-1000 | 0.960                        | 20                    | 33.8g  | Yes      | 4                                                             | 7      | 12     | 20     | 21      | 22      | 16      | 14      |

### Attenuator Insertion Loss Data



W: [www.bwfabrications.com](http://www.bwfabrications.com)

Group

## Kitchen Ventilation System

| MOVING NO. | SCALE |
|------------|-------|
|------------|-------|