

Legend:

- | | |
|---|--|
|  | MAINS COLD WATER OUTLET |
|  | HOT WATER OUTLET |
|  | CAT 5 COLD WATER OUTLET |
|  | ELECTRIC WATER HEATER AS HEATRAE SADA MULTIPPOINT
10.572Hx26.5Wx25.2Dx6.3W 5.22dA7 TIMELOCK |
|  | ELECTRIC SHOWER AS MIRA ELITE 5E.9 8kW |
|  | WATER LEAK DETECTION SYSTEM |
| ZIP | ZIP HYDRO TAP |
| DW | DISH WASHER |
|  | ELECTROMAGNETIC WATER CONDITIONER |
|  | CAT 5 B REAK TANK AND BOOSTER SET AS ARROW VALVES
MDI B REAK 400MMx25Hx26D. WALL MOUNTED C/W
FROST PROTECTION AND SYSTEM INSULATED COVER |
|  | STOP COCK |
|  | SOLENOID VALVE |
|  | WATER SUB METER |
|  | PIPE RISE |
|  | PIPE DROP |
|  | FROM ABOVE |
|  | TO ABOVE |
|  | TO BELOW |
|  | PIR |



Notes:

1. DO NOT SCALE THIS DRAWING. ALL DIMENSIONS IN MILLIMETERS UNLESS OTHERWISE STATED.
2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECT'S STRUCTURAL ENGINEERS AND MBE DRAWINGS AND THE MBE SPECIFICATION, SAMPLES SHEET AND ROOM DATA SHEETS.
3. ALL ITEM OF EQUIPMENT SHALL BE INSTALLED AS TO THE MANUFACTURER'S RECOMMENDATIONS.
4. ALL INFORMATION AND LAYOUTS DETAILED ON THIS DRAWING ARE SUBJECT TO SITE DIMENSION CHECKS.

REVISION	DATE	COMMENTS
P03	16.09.25	Revised layout

PROJECT
Sussex Down Carehome
CLIENT



Water Services Layout

First Floor

DRAWN BY:	APPROVED BY:	DATE	SCALE - A1
CRA	SPT	04.05.24	1:50
DRAWING NUMBER			REVISION
043RSD 510 011			P03