From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 19 June 2024 17:15
To: Planning
Subject: Hydrant Condition - DC/24/0739 - Builders Yard Mead Farm Stane Street Slinfold West Sussex
Attachments: HC - DC240739 Builders Yard Mead Farm.docx

Categories: Consultations

FAO: Marie Riggs

Dear Marie,

Please find attached a planning condition for application no: DC/24/0739 for the requirement of additional fire hydrants for the proposed development.

Currently, the nearest hydrant is over 330 metres away from the proposed dwelling. The supply of water for firefighting for a domestic premises should be within 150 metres.

Evidence will also be required that Fire Service vehicle access meets with the requirements identified in Approved Document B Volume 1 2019 Edition: B5 Section 13, including Table 13.1.

Kind regards
Marik

Marik Waddup
Protection Support Officer
West Sussex Fire & Rescue Service

Phone 0330 222 4499
Web www.westsussex.gov.uk/fire
Email frswaterandaccess@westsussex.gov.uk

Worthing Fire Station, Ardsheal Road, Worthing, BN14 7RN

My pronouns are he/him/his

LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.

WEST SUSSEX COUNTY COUNCIL
WEST SUSSEX FIRE AND RESCUE SERVICE

HYDRANT CONDITION CONSULTATION WITH PLANNING AUTHORITY

Date: 19/06/2024

To: Marie Riggs From: Marik Waddup

Planning Ref: **DC/24/0739**

Address: Builders Yard Mead Farm Stane Street Slinfold West Sussex

Description: Variation of Condition 1 of previously approved application DC/22/0370 (Redevelopment of existing builder's yard and erection of 1no detached dwelling and a detached carport/garage) Removal of existing south facing dormers, installation of solar panels and replace north facing sloping roof with flat roof to accommodate tilting south facing solar panels.

Date of visit: N/A

RECOMMENDATION

Advice:	x	Modification:		More Information:	
Objection:		No Objection:		Refusal:	

Total number of hydrants required: Unknown

This application has been dealt with in accordance with the statutory obligation placed upon Fire and Rescue Service by the following act;

Fire and Rescue Services Act 2004
Part 5, 38: Duty to secure water supply etc.

1) A fire and rescue authority must take all reasonable measures for securing that an adequate supply of water will be available for the authority's use in the event of fire.

This proposal has been considered by means of desktop study, using the information and plans submitted with this application, in conjunction with other

available WSCC mapping and Fire and Rescue Service information. A site visit can be arranged on request.

I refer to your consultation in respect of the above planning application and would provide the following comments:

1) Prior to the commencement of the development details showing the proposed location of the required fire hydrants shall be submitted to and approved in writing by the Local Planning Authority in consultation with West Sussex County Council's Fire and Rescue Service. These approvals shall not be unreasonably withheld or delayed.

2) Prior to the first occupation of any dwelling/unit forming part of the proposed development that they will at their own expense install the required fire hydrants (or in a phased programme if a large development) in the approved location to BS 750 standards or stored water supply and arrange for their connection to a water supply which is appropriate in terms of both pressure and volume for the purposes of firefighting.

The fire hydrants shall thereafter be maintained as part of the development by the water undertaker at the expense of the Fire and Rescue Service if adopted as part of the public mains supply (Fire Services Act 2004) or by the owner / occupier if the installation is retained as a private network.

As part of the Building Regulations 2004, adequate access for firefighting vehicles and equipment from the public highway must be available and may require additional works on or off site, particularly in very large developments. (BS5588 Part B 5) for further information please contact the Fire and Rescue Service.

If a requirement for additional water supply is identified by the Fire and Rescue Service and is subsequently not supplied, there is an increased risk for the Service to control a potential fire. It is therefore recommended that the hydrant condition is implemented.

Reason: In the interests of amenity and in accordance with policy CP13 of the Horsham District Local Development Framework; Core Strategy and DC40 of the Horsham District Local Development Framework: General Development Control Policies (2007) and policy CP3 of the Horsham District Local Development Framework Core Strategy (2007), HDPF Policies 33 and 39 and in accordance with The Fire & Rescue Service Act 2004.

Marik Waddup
Water and Access Support Officer

Email: frs.waterandaccess@westsussex.gov.uk