

WATER EFFICIENCY & SANITARY FITTINGS REPORT

Building Regulations Part G

Local Authority: Horsham District Council

Property: 2-Storey Barn – Utility Room and WC

WC – Photo 1

Assumed flush volumes: 6.0 / 4.0 litres



Basin Mixer Tap – Photo 2

Assumed flow rate: 5.0 l/min



Utility Sink Mixer Tap – Photo 3
Assumed flow rate: 6.0 l/min



Washing Machine – Photo 4
Water-efficient domestic appliance

