From: Sean.Rix
Sent: 11 July 2024 12:10
To: Marie.Riggs; Planning
Subject: RE: DC/23/2218 2 Old School Cottages Lynwick Street Rudgwick

Categories: Consultations

Dear Marie,

Following discussions with the applicant and their designer I am satisfied the revised design, although not ideal, will not harm the non-designated heritage asset or the setting of the adjacent listed building. Notwithstanding the stated use of interlocking concrete roof tiles on the plans it will be necessary to use a traditional roof covering. I imagine a natural slate will be best given the relatively shallow roof pitch. I have suggested conditions below.

Regards,
Seán

LB01 Samples of External Materials and Finishes

Pre-Commencement Condition: Prior to relevant work beginning, the following details shall have been submitted to and approved in writing by the Local Planning Authority. The relevant works must not be executed other than in complete accordance with these approved details:

Specifications of external materials and surface finishes.

Reason: As this matter is fundamental to ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB02 Roof Detailing/Junctions

Regulatory Condition: The new roof will be laid with clay tiles or a natural slate. The roof junctions at ridge, hips, valleys, eaves and verges shall be built to reflect traditional detailing cut verges.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB03 Windows

Regulatory Condition: The new windows fitted in the extension hereby permitted shall have casements flush fitted with their frames if manufactured in timber or plastic.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB04 Roof Lights

Regulatory Condition: Any roof lights fitted shall be metal framed and sit flush with the roof slope.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB05 Rainwater Goods

Regulatory Condition: All new and replacement rainwater goods shall be cast iron or cast aluminium or cast effect plastic.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

Seán Rix
Senior Conservation Officer
Specialists Team - Strategic Planning

[redacted]

Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

[redacted]

Subject: DC/23/2218 2 Old School Cottages Lynwick Street Rudgwick

Dear Marie,

Comments attached.

Regards,
Seán

Seán Rix
Senior Conservation Officer

[redacted]

Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton