[redacted]

Sent: 11 July 2024 15:32
To: Planning
Subject: Discharge of Planning condition - DISC/24/0174 Greenway Academy Greenway Horsham West Sussex RH12 2JS

Categories: Consultations

FAO: Amanda Wilkes

Dear Amanda,

Having viewed the details for DC/22/1954 and DISC/24/0174 for the discharge of condition 6 - Fire Appliance Access Strategy, providing a fire appliance can gain access to over 45m of the footprint of the new building in accordance with approved document B and compliance with the requirements of
BB100 section 8.3. The condition raised will be met. Any gateway or narrowing will need a straight-line approach to ensure the fire appliance can pass through the narrowing.

Regards

Ian

Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
[redacted]
Web www.westsussex.gov.uk/fire
Email frs.waterandaccess@westsussex.gov.uk
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

[redacted]



[redacted]