HORSHAM DISTRICT COUNCIL CONSULTATION

TO:	Horsham District Council – Planning Dept
LOCATION:	Gatewick Lodge, Broadford Bridge Road, West Chiltington
DESCRIPTION:	
REFERENCE:	DC/24/0842
RECOMMENDATION:	~~Advice /~~ No Objection ~~/ Objection / More Information / Modification / Refusal~~
SUMMARY OF COMMENTS & RECOMMENDATION: No objection in principle.	
MAIN COMMENTS: Dear Steve, I am satisfied the additional accommodation and increase in size over the permitted scheme will not harm the setting of the adjacent listed buildings. I have included the same conditions placed on DC/24/0192 plus an additional condition to cover details of the pitched dormers. Regards, Seán	

ANY RECOMMENDED CONDITIONS:

LB07 Submission of Details

Pre-Commencement Condition: No relevant works shall commence until the following details have been submitted to and approved in writing by the Local Planning Authority. The works must not be executed other than in complete accordance with these approved details:

Drawings to a scale not smaller than 1:5 fully describing:

Dormer details including sections through:

- roof ridge
- valleys
- eaves
- verges

Reason: As this matter is fundamental to ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB02 Roof Detailing/Junctions

Regulatory Condition: The new roof junctions at ridge, valleys, eaves and verges shall be built to reflect traditional detailing as found on the existing principal roof including exposed rafter feet and purlins, cut verges, valley tiles and hogs back or half round ridge tiles.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB03 Windows

Regulatory Condition: The new windows fitted in the extension hereby permitted shall have casements flush fitted with their frames if manufactured in timber or plastic.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB04 Roof Lights

Regulatory Condition: The roof lights hereby permitted shall be metal framed and sit flush with the roof slope.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB05 Rainwater Goods

Regulatory Condition: All new and replacement rainwater goods shall be cast iron or cast aluminium or cast effect plastic.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

NAME:	Seán Rix
DEPARTMENT:	Conservation
DATE:	27.06.24